

3070c
05-19-88

CITY OF BELLEVUE, WASHINGTON

ORDINANCE NO. 3904

AN ORDINANCE establishing requirements for the installation of automatic fire sprinkler systems in certain Group R, Division 1 Occupancies two or more stories in height; and adding a new Section 23.10.124 to the Bellevue City Code.

THE CITY COUNCIL OF THE CITY OF BELLEVUE, WASHINGTON, DOES ORDAIN AS FOLLOWS:

Section 1. A new Section 23.10.124 is added to Chapter 23.10 of the Bellevue City Code to read as follows:

23.10.124 Uniform Building Code Section 3802 Amended - Sprinkler Systems.

Section 3802 of the Uniform Building Code, as adopted by this chapter, is amended by the addition of a new subsection 3802 (h) to read as follows:

- (h) Group R, Division 1 Occupancies. This subsection 3802(h) shall apply to certain Group R, Division 1 Occupancies and shall be in addition to and supplemental to any requirements for Group R, Division 1 Occupancies set forth in subsection 3802(b). An automatic sprinkler system shall be installed throughout buildings containing Group R, Division 1 Occupancies that are two stories in height and contain 5 or more dwelling units or guest rooms or that are three or more stories in height regardless of the number of dwelling units or guest rooms. For the purposes of this subsection 3802(h), portions of buildings separated by one or more area separation walls will not be considered a separate building.

3070c
05-19-88

Section 2. This ordinance shall take effect and be in force thirty days after final passage by the City Council.

PASSED by the City Council this 20th day of June, 1988, and signed in authentication of its passage this 20th day of June, 1988.

(SEAL)

Nan Campbell
Nan Campbell, Mayor

Approved as to form:

Richard L. Andrews, City Attorney

Richard L. Kirkby
Richard L. Kirkby, Assistant City Attorney

Attest:

Marie K. O'Connell
Marie K. O'Connell, City Clerk

Published June 24, 1988