

**CITY COUNCIL STUDY SESSION ITEM**

**SUBJECT**

Ordinance No. \_\_\_\_\_ repealing Chapter 23.30 of the Bellevue City Code (BCC); adopting a new Chapter 23.30 that adopts the 2008 Edition of the National Electrical Code and the Washington Cities Electrical Code; amending Chapter 23.05 BCC relating to construction code administration, establishing an effective date and severability.

**STAFF CONTACTS**

Mike Brennan, Director	452-4113
Gregg Schrader, Building Official	452-6451
Bob Lloyd, Inspection Supervisor	452-7911
Catherine A. Drews, Legal Planner <i>Development Services Department</i>	452-6134

**POLICY ISSUES**

Should the City amend the Electrical Code (Chapter 23.30 BCC) and certain provisions of the Construction Code (Chapter 23.05 BCC), by adopting the 2008 Edition of the National Electrical Code and the Washington Cities' Electrical Code (November 12, 2009)?

**DIRECTION NEEDED FROM COUNCIL**

<input type="checkbox"/>	Action
<input checked="" type="checkbox"/>	Discussion
<input checked="" type="checkbox"/>	Information

After review and discussion at this Study Session, staff requests Council direction to bring the amendments forward for action at the February 1, 2010 meeting.

**BACKGROUND/ANALYSIS**

The City administers an electrical code program that must provide codes and standards that are equal or more restrictive than those enforced by the State. On December 31, 2008 the State adopted the 2008 Edition of the National Electrical Code (NEC) triggering the requirement for enforcement statewide; the Development Services Department has been enforcing the 2008 NEC since adoption by the State. Currently Section 23.05.015 of the Bellevue City Code references the 2005 National Electric Code, but provides specific authority to enforce a more current edition of the NEC when adopted by the State. The proposed ordinance (Attachment A) will formally adopt the 2008 National Electric Code with administrative provisions. Unlike prior years, when the City amended and adopted the NEC without coordination with other jurisdictions, this year staff recommends that the City adopt the Washington Cities Electrical Code, developed in collaboration with the member cities of MyBuildingPermit.com and the Washington Association of Building Officials. As discussed below, adoption of this new,

common electrical code will not only meet the requirements of state law, but has the added advantage of providing consistency among the jurisdictions that adopt it, thereby providing a more consistent and efficient permitting experience for customers. The proposed code changes will apply to permits issued for new buildings and remodels to existing buildings.

### State Regulation of Electrical Work and Inspections

Although the state regulates electrical work and inspections, RCW 19.28.010(3) allows jurisdictions to adopt and enforce local ordinances for administration of electrical installation and inspection programs. All jurisdictions that have adopted a local ordinance for administration of electrical inspection programs are required to maintain codes and standards that are equal to, higher or better than those enforced by the state under the provisions found in Chapter 19.28 RCW. The City's adopted ordinance is codified in the City's Electrical Code, Chapter 23.30 BCC.

### Development of the Washington Cities Electrical Code

Member cities from MyBuildingPermit.com (MBP) and the Washington Association of Building Officials formed an electrical committee open to any Washington city or county wishing to participate. The jurisdictions participating in the MBP Electrical Committee include Bellevue, Bellingham, Burien, Des Moines, Kirkland, King County, Lacey, Longview, Marysville, Mercer Island, Olympia, Redmond, Renton, SeaTac, Seattle, Tukwila, and Vancouver. The committee's purpose is to develop and maintain a single, common code for participating cities, align code administrative processes, jointly produce public information handouts, and sponsor training for contractors, design professionals, and inspectors. The committee, which is chaired by Bob Lloyd, City of Bellevue Inspection Supervisor, has made significant headway in aligning participating cities' code adoption ordinances and developing a consistent and efficient permitting and inspection experience for their customers.

To develop the code, the committee compared the 2008 NEC, city electrical ordinances, the state electrical installation rules, and local/regional concerns. From this effort, "The Washington Cities Electrical Code" (WCEC) (Attachment B), was created. This new electrical code provides cities with a comprehensive, efficient document that creates an equal, higher, or better standard as required by Chapter 19.28 RCW and state rules; and offers the following advantages:

- (1) Formally adopts the 2008 edition of the NEC and technical amendments made by the state as the minimum standard for electrical installations in Bellevue keeping the City's electrical ordinance consistent with state electrical law.
- (2) The WCEC creates a consolidated set of administrative and procedural standards that integrate the electrical code into the city's broader construction code enforcement program, removing the administrative and procedural state rules that are not enforceable by cities. A substantial number of the requirements in Chapter 296-46B WAC relate to the state's administration of their electrical inspection program, the administration of contractor licensing,

electrician certification programs, and administration of approved electrical products testing laboratories.

- (3) The WCEC is written in the same format as the NEC to eliminate any conflict between a state rule, the NEC, and city ordinances.
- (4) The WCEC institutes changes that will maintain consistency between cities that adopt it; while implementing strategies to better align our code and administration practices.

#### Significant technical changes between the 2005 and 2008 NEC

##### *NEC 210.12 (B)*

The 2008 NEC expands the requirement for Arc-Fault Circuit Interrupters (AFCI's) to include most 15 and 20 ampere circuits in residential occupancies. AFCI's are devices designed to protect against fires caused by arcing faults in residential electrical wiring. According to the U.S. Fire Administration, each year home electrical problems cause about 70,000 fires, resulting in 485 deaths and \$868 million in property loss. Arcing faults are one of the major causes of these fires. Underwriters Laboratories, the National Association of State Fire Marshals (NASFM), and the U.S. Consumer Product Safety Commission support the use of AFCI's to help reduce the number of residential fires caused by electrical arcing.

##### *NEC 406.11*

The 2008 NEC adds a requirement that all 125 volt, 15 and 20 ampere receptacles in residential occupancies be listed as tamper-resistant. The NEC code making panel added the requirement after reviewing the US Consumer Product Safety Commission's report that indicated from 1991 to 2001 over 24,000 children were injured when they inserted foreign objects into energized electrical receptacles. This means that on average 2,400 children per year, or 7 children per day, were treated in hospitals for injuries from tampering with energized electrical receptacles.

#### Summary

The proposed ordinance will amend the City of Bellevue construction code by adopting the 2008 Edition of the NEC and "The Washington Cities Electrical Code," and amending the administrative provisions in Chapter 23.05 BCC, to be consistent with other cities in the region. Adopting the WCEC replaces the majority of the current Chapter 23.30 BCC, some of which is duplicative and potentially in conflict with other administrative provisions in the City's Construction Code.

#### **ALTERNATIVES**

1. Direct staff to return with the final proposed ordinance amending the Electrical Code for Council adoption at the February 1, 2010 meeting.

2. Direct staff to modify the proposed amendments pursuant to Council direction and return for further discussion.

**RECOMMENDATION**

Direct staff to return with the proposed ordinance amending the Electrical Code Chapter of the Construction Code for Council adoption at the February 1, 2010 meeting.

**ATTACHMENTS**

- A. Proposed Ordinance No. \_\_\_\_\_ (Repealing Chapter 23.30 BCC, adopting a new Chapter 23.30 BCC, and amending Chapter 23.05 BCC).
- B. The Washington Cities Electrical Code (November 12, 2009).

**AVAILABLE IN COUNCIL OFFICE**

BCC Amendment File No. 09129265-AB

-ORD  
01/05/10

**DRAFT**

CITY OF BELLEVUE, WASHINGTON

ORDINANCE NO. \_\_\_\_\_

AN ORDINANCE repealing chapter 23.30 of the Bellevue City Code in its entirety and replacing it was a new chapter; amending Chapter 23.05 of the Bellevue City Code, specifically amending sections 23.05.040, 23.05.050, 23.05.090, 23.05.105, 23.05.110, 23.05.130, 23.05.190; providing for severability; and establishing an effective date.

WHEREAS, the City of Bellevue includes electrical inspection as a component of its comprehensive building inspection program; and

WHEREAS, Chapter 19.28 RCW requires the City to have in place codes and standards that are equal, higher or better than the state electrical code WAC 294-46B; and

WHEREAS, the state has adopted and amended the 2008 National Electrical Code (NEC), while the Bellevue Electrical Code is based on the 2005 NEC; and

WHEREAS, adoption of this ordinance will maintain the required equivalency under state law for the City's electrical program; and

WHEREAS, the MyBuildingPermit.com and the Washington Association of Building Officials' electrical committee has created a new code called the Washington Cities Electrical Code which adopts the 2008 National Electrical Code and better addresses the concerns of cities;

WHEREAS, the City of Bellevue has complied with the State Environmental Policy Act (SEPA), Chapter 43.21C RCW, and the City's Environmental Procedures Code, BCC 22.02; now, therefore,

THE CITY COUNCIL OF THE CITY OF BELLEVUE, WASHINGTON,  
DOES ORDAIN AS FOLLOWS:

Section 1. Chapter 23.30 of the Bellevue City Code is hereby repealed in its entirety and replaced with the following new chapter:

**23.30.010 Short title.**

This chapter shall be known as the electrical code of the city of Bellevue, which is hereinafter referred to as the "City of Bellevue Electrical Code," "electrical code" or as "this chapter."

**23.30.015 Washington Cities Electrical Code Adopted.**

A. The November 12, 2009 edition of the Washington Cities Electrical Code Part 1 and Part 3, but excluding Part 2 Administration, as published by the Washington Association of Building Officials is adopted and shall be applicable within the city, as amended, added to and excepted in this chapter.

**23.30.020 Conflicts**

A. The requirements of this chapter will be observed where there is any conflict between this chapter and the National Electrical Code (NFPA 70), Centrifugal Fire Pumps (NFPA 20), the Emergency and Standby Power Systems (NFPA 110), ANSI/TIA/EIA 568-B, ANSI/TIA/EIA 569-A, ANSI/TIA/EIA 607, or ANSI/TIA/EIA 570.

B. The National Electrical Code will be followed where there is any conflict between standard for Installation of Stationary Pumps for Fire Protection (NFPA 20), standard for Emergency and Standby Power Systems (NFPA 110), ANSI/TIA/EIA 568-B, ANSI/TIA/EIA 569-A, ANSI/TIA/EIA 607, ANSI/TIA/EIA 570-B, and the National Electrical Code (NFPA 70).

C. In accordance with RCW 19.28.010(3), where the State of Washington, Department of Labor and Industries adopts a more current edition of the National Electrical Code (NFPA 70) the building official may supplement use of this Code with newly adopted editions of the National Electrical Code. Provisions in the annex chapters of the National Electrical Code shall not apply unless specifically referenced in the adopting ordinance.

**23.30.030 Applicability**

A. The electrical code covers the installation of electric conductors, electric equipment and additions, alterations, modifications, or repairs to existing electrical installations for the following:

- (1) Electric conductors, electric equipment, and electrical raceways installed within or on public and private buildings, property or other structures.
- (2) Signaling and communications conductors and equipment, telecommunications conductors and equipment, fiber optic cables, and

raceways installed within or on public and private buildings, property or other structures.

(3) Yards, lots, parking lots, and industrial substations.

(4) Temporary electrical installations for use during the construction of buildings.

(5) Temporary electrical installations for carnivals, conventions, festivals, fairs, traveling shows, the holding of religious services, temporary lighting of streets, or other approved uses.

(6) Installations of conductors and equipment that connect to a supply of electricity.

(7) All other outside electrical conductors on the premises.

(8) Optional standby systems derived from portable generators.

**B. Exception:**

Installations under the exclusive control of electric utilities for the purpose of communication, transmission, and distribution of electric energy located in buildings used exclusively by utilities for such purposes or located outdoors on property owned or leased by the utilities or on public highways, streets, roads, etc., or outdoors by established rights on private property.

It is the intent of this section that this code covers all premises' wiring or wiring other than utility owned metering equipment, on the load side of the service point of buildings, structures, or any other premises not owned or leased by the utility. Also, it is the intent that this code covers installations in buildings used by the utility for purposes other than listed in above, such as offices buildings, warehouses, garages, machine shops, and recreational buildings which are not an integral part of a generating plant, substation, or control center.

**23.30.040 Maintenance Requirements**

Electrical systems, equipment, materials and appurtenances, both existing and new, and parts thereof shall be maintained in proper operating condition in accordance with the original design and in a safe, hazard-free condition. Devices or safeguards that are required by this chapter shall be maintained in compliance with the code edition under which installed. The owner or the owner's designated agent shall be responsible for the maintenance of the electrical systems and equipment. To determine compliance with this provision, the Building official shall have the authority to require that the electrical systems and equipment be re-inspected.

Section 2. Section 23.05.040 of the Bellevue City Code is hereby amended to read as follows:

**23.05.040 Applicability.**

A. General. This chapter applies to the administration of the technical codes, as adopted by the city in other chapters of this title. Provisions in the appendices of the technical codes shall not apply unless specifically adopted.

B. Conflicting Provisions.

1. Where there is a conflict between the provisions or requirements of this chapter, or the technical codes, and other codes or laws, this chapter, or the technical codes as the case may be, shall govern.

2. Where conflicts occur between the technical codes, those provisions providing the greater safety to life shall govern, or if life safety is not at issue, the more restrictive provision shall govern.

3. Where, in any specific case, different sections of the technical codes specify different materials, methods of construction or other requirements, the hierarchy of the codes named in RCW 19.27.031, now or as hereafter amended, shall govern. In the event that the conflict is between provisions for which such hierarchy of codes is not determinative, the most restrictive provision shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern.

4. Where enforcement of a code provision would violate the conditions of the listing of the equipment or appliance, the conditions of the listing and manufacturer's instructions shall apply.

Section 3. Section 23.05.050 of the Bellevue City Code is hereby amended to read as follows:

**23.05.050 Existing structures.**

A. Compliance with Technical Codes. Buildings, structures and their building service equipment to which additions, alterations or repairs are made shall comply with all the requirements of the technical codes for new facilities, except as specifically provided in this section.

B. Additions, Alterations or Repairs.

1. Additions, alterations or repairs may be made to a building, structure, or its building service equipment without requiring the existing building, structure, or its building service equipment to comply with all the requirements of the technical codes, provided the addition, alteration or repair conforms to the requirements of the technical codes for a new building, structure, or new building service equipment. Additions, alterations or repairs shall not be made to an existing building, structure, or building service equipment which will cause the existing building, structure, or building service equipment to be in violation of the provisions of the technical codes nor shall such additions, alterations or repairs cause the existing building, structure, or building service equipment to become unsafe.

2. Building service equipment which was lawful under the technical codes current at the time such equipment was installed may be used, maintained or repaired if the use, maintenance or repair is in accordance with the original design and a hazard to life, health or property has not been created by such building service equipment.

C. Existing Occupancy. The legal occupancy of any structure existing on the date of adoption of this chapter and the technical codes shall be permitted to continue without change, except as is specifically covered in this chapter and the technical codes, the International Fire Code, or if continued use poses a danger to life, health and safety of the occupants and the public, as is determined by the building official or fire official.

D. Change in Use. No change will be made in the character of occupancies or use of any building that would place the building in a different division of the same group or occupancy or in a different group of occupancies, unless such building is made to comply with the requirements of this chapter and the technical codes for such division or group of occupancy.

Exception: The character of the occupancy of existing buildings may be changed subject to the approval of the building official, and the building may be occupied for purposes in other groups without conforming to all the requirements of this chapter and the technical codes for those groups, provided the new or proposed use is less hazardous, based on life and fire risk, than the existing use.

No change in the character of occupancy of a building shall be made without a certificate of occupancy, as required in BCC 23.05.140. The building official may issue a certificate of occupancy pursuant to the intent of the above exception without certifying that the building complies with all provisions of this code.

E. Moved buildings or structures.

1. Buildings or structures intended to be relocated within or into the city must be inspected by the code official for compliance with the codes and standards adopted in this chapter prior to being relocated or moved. The owner of the building or structure must obtain a building permit and further must agree to correct all deficiencies identified by the inspection prior to moving the building. All deficiencies must be corrected before electric power is connected to the building.

2. Nonresidential buildings or structures moved into the jurisdiction must be inspected to ensure compliance with current requirements of this Code.

3. Residential buildings or structures wired in the U.S., to NEC requirements, and moved into the jurisdiction must be inspected to ensure compliance with the NEC requirements in effect at the time and place the original wiring was made. The building or structure must be inspected to ensure compliance with all current requirements of chapter 19.28 RCW and the rules developed by the department if:

a. The original occupancy classification of the building or structure is changed as a result of the move; or

b. The building or structure has been substantially remodeled or rehabilitated as a result of the move.

4. Residential buildings or structures wired in Canada to Canadian Electrical Code (CEC) standards and moved into the jurisdiction must be inspected to ensure compliance with the following minimum safety requirements:

a. Service, service grounding, and service bonding must comply with this Code.

- b. Canadian Standards Association (CSA) listed Type NMD cable is allowed with the following qualifications:
- i. CSA listed Type NMD cable, American Wire Gauge #10 and smaller installed after 1964 utilizing an equipment grounding conductor smaller than the phase conductors, must be:
    - (a) Replaced with a cable utilizing a full-size equipment grounding conductor; or
    - (b) Protected by a ground fault circuit interrupter protection device.
  - ii. CSA listed Type NMD cable, #8 AWG and larger, must:
    - (a) Utilize an equipment grounding conductor sized according to the requirements of the NEC in effect at the time of the installation;
    - (b) Be protected by a ground fault circuit interrupter protection device; or
    - (c) Be replaced.
- c. Other types of wiring and cable must be:
- i. Replaced with wiring listed or field evaluated in accordance with U.S. standards by a laboratory approved by the department; or
  - ii. Protected by a ground fault circuit interrupter protection device and arc fault circuit protection device.
- d. Equipment, other than wiring or panelboards, manufactured and installed prior to 1997 must be listed and identified by laboratory labels approved by the department or CSA labels.
- e. All panelboards must be listed and identified by testing laboratory labels approved by the department with the following qualifications:
- i. CSA listed panelboards labeled "Suitable for Use as Service Equipment" will be considered to be approved as "Suitable for Use only as Service Equipment."
  - ii. CSA listed panelboards must be limited to a maximum of 42 circuits.
  - iii. CSA listed panelboards used as lighting and appliance panelboards as described in the NEC, must meet all current requirements of the NEC and this chapter.
- f. Any wiring or panelboards replaced or changed as a result of the move must meet current requirements of chapter 19.28 RCW and this chapter.
- g. The location, type, and ground fault circuit interrupter protection of receptacles and equipment in a bathroom, kitchen, basement, garage, or outdoor area must meet the Washington requirements in effect at the time the wiring was installed.
- h. 4, 15-ampere, kitchen small appliance circuits will be accepted in lieu of 2, 20-ampere, kitchen small appliance circuits. Receptacles will not be required to be added on kitchen peninsular or island counters.
- i. Spacing requirements for all other receptacles must meet the Washington requirements in effect at the time the wiring was installed.
  - j. Receptacles installed above baseboard or fixed wall space heaters must be removed and the outlet box covered with a blank cover. The receptacle is required to be relocated as closely as possible to the existing location.

- k. Lighting outlet and switch locations must meet the Washington requirements in effect at the time the wiring was installed.
- l. Dedicated 20-ampere small appliance circuits are not required in dining rooms.
- m. Electric water heater branch circuits must be adequate for the load.
- n. The location, type, and circuit protection of feeders must meet the Washington State requirements in effect at the time the wiring was installed.

Section 4. Section 23.05.090 of the Bellevue City Code is hereby amended to read as follows:

**23.05.090 Permits required.**

A. Technical Codes Other than the Electrical Code – Required. Any person who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this chapter and the technical codes, or to cause any such work to be done, shall first make application to the building official and obtain the required permit.

.....

C. The Electrical Code – Required. In accordance with Chapter 19.28 RCW, an electrical permit is required for

In accordance with Chapter 19.28 RCW, an electrical permit is required for the following installations:

1. The installation, alteration, repair, replacement, modification or maintenance of all electrical systems, wire and electrical equipment regardless of voltage.
2. The installation and/or alteration of low voltage systems defined as:
  - a. NEC, Class 1 power limited circuits at 30 volts maximum.
  - b. NEC, Class 2 circuits powered by a Class 2 power supply as defined in NEC 725.41(A).
  - c. NEC, Class 3 circuits powered by a Class 3 power supply as defined in NEC 725.41(A).
3. Telecommunications Systems.
  - a. All installations of telecommunications systems on the customer side of the network demarcation point for projects greater than 10 telecommunications outlets.
  - b. All backbone installations regardless of size and all telecommunications cable or equipment installations involving penetrations of fire barriers or passing through hazardous locations require permits and inspections.
  - c. The installation of greater than 10 outlets and the associated cables along any horizontal pathway from a telecommunications closet to work areas during any continuous 90-day period requires a permit and inspection.

d. In R1 and R2 occupancies as defined in the building code, permits and inspections are required for all backbone installations, all penetrations of fire resistive walls, ceilings and floors; and installations of greater than 10 outlets in common areas.

e. Definitions of telecommunications technical terms will come from Chapter 19.28 RCW, the currently adopted WAC rules, EIA/TIA standards, and the National Electrical Code.

D. The Electrical Code – Work Exempt from Permit. Certain work is exempt from the permit requirements of this chapter and the electrical code. Exemptions from permit requirements of this chapter and the electrical code shall not be deemed to grant authorization for any work to be done in any manner in violation of the provisions of this chapter, the technical codes or any other laws or ordinances of the city. An exemption from the permit requirements of one technical code does not exempt work from the permit requirements of other technical codes or other laws or ordinances of the city

Permits shall not be required for the following:

1. Emergency Repairs. Where equipment replacements and equipment repairs must be performed in an emergency situation posing a significant and immediate risk to life and safety, or a significant and immediate risk of loss to property, the permit application shall be submitted within the next working business day to the building official.

2. An electrical permit shall not be required for the following:

a. Portable motors or other portable appliances energized by means of a cord or cable having an attachment plug end to be connected to an approved receptacle when that cord or cable is permitted by the National Electrical Code.

b. Repair or replacement of fixed motors, transformers or fixed approved appliances or devices rated 50 amperes or less which are like-in-kind in the same location.

c. Temporary decorative lighting, when used for a period not to exceed 45 days and removed at the conclusion of the 45-day period.

d. Repair or replacement of current-carrying parts of any switch, conductor or control device which are like-in-kind in the same location.

e. Repair or replacement of attachment plug(s) and associated receptacle(s) rated 50 amperes or less which are like-in-kind in the same location.

f. Repair or replacement of any over current device which is like-in-kind in the same location.

g. Repair or replacement of electrodes or transformers of the same size and capacity for signs or gas tube systems.

h. Removal of electrical wiring.

i. Telecommunications Systems.

i. Telecommunications outlet installations within the individual dwelling units of group R1 and R2 occupancies as defined by the building code;

ii. All telecommunications installations within R3 and R4 occupancies as defined in the building code;

iii. The installation or replacement of cord and plug connected telecommunications equipment or for patch cord and jumper cross-connected equipment.

j. Listed wireless security systems where power is supplied by a listed Class 2 plug in transformer installed in R3 and R4 occupancies.

k. The installation, alteration or repair of electrical wiring, apparatus or equipment for the generation, transmission, distribution or metering of electrical energy or in the operation of signals for the transmission of intelligence by a public or private utility in the exercise of its function as a serving utility.

l. Induction detection loops described in WAC 296-46B-300(2) and used to control gate access devices.

m. Heat cable repair.

n. Travel trailers.

o. Unless specifically noted, the exemptions listed do not include: The replacement of an equipment unit, assembly, or enclosure that contains an exempted component or combination of components (i.e., electrical furnace/heat pumps, industrial milling machine, etc.).

3. Exemption from the permit requirements of this code shall not be deemed to grant authorization for work to be done in violation of the provisions of this code or other laws or ordinances of this jurisdiction.

Section 5. Section 23.05.110 of the Bellevue City Code is hereby amended to read as follows:

**23.05.110 Temporary structures and uses.**

A. Temporary Permits – Technical Codes Other than the Electrical Code. The building official is authorized to issue a permit for temporary structures and temporary uses. Such permits shall be limited as to time of service, but shall not be permitted for more than 180 days. The building official is authorized to grant extensions for demonstrated cause. Additional permits may be required under the technical codes or other city codes and regulations, including the Land Use Code. All temporary installations allowed under this section shall be made in accordance with the requirements of this chapter and the technical codes; provided, that the building official may permit deviations which will not permit hazards to life or property; and further provided, that whenever such hazards are deemed by the building official to exist, the building official may at once rescind or cancel the permit covering such installation and disconnect, or order the disconnection of, all energy to such equipment.

B. Temporary Permits – Electrical Code. If the building official finds that the safety of life and property will not be jeopardized, permits may be issued for temporary electrical installations for use during the construction of buildings or for carnivals, conventions, festivals, fairs, the holding of religious services, temporary lighting of streets, or other approved uses. Permission to use such temporary installation shall not be granted for a greater length of time than 90 days, except that a permit for a temporary installation to be used for constructing of a building may be issued for the period of construction. Should such temporary lighting be over the street area, the

proper authorization for such use of the street must first be obtained. Additional permits may be required under the technical codes or other city codes and regulations, including the Land Use Code. All temporary electrical installations allowed under this section shall be made in accordance with the requirements of this chapter and the technical codes; provided, that the building official may permit deviations which will not permit hazards to life or property; and further provided, that whenever such hazards are deemed by the building official to exist, the building official may at once rescind or cancel the permit covering such installation and disconnect, or order the disconnection of all energy to such equipment.

C. For temporary electrical installations, the city will consider a permit applicant to be the owner per RCW 19.28.261 under the following conditions:

Any person firm, partnership, corporation, or other entity registered as a general contractor under chapter 18.27 RCW will be permitted to install a single electrical service per address for the purposes of temporary power during the construction phase of a project, when all of the following conditions are met:

(1). The installation is limited to the mounting and bracing of a pre-assembled pole or pedestal mounted service, the installation of a ground rod or ground plate, and the connection of the grounding electrode conductor to the ground rod or plate;

(2). The total service size does not exceed 200 amperes, 250 volts nominal;

(3). The service supplies no feeders;

(4). Branch circuits not exceeding 50 amperes each are permitted, provided such branch circuits supply only receptacles that are either part of the service equipment or are mounted on the same pole;

(5). The general contractor owns the electrical equipment;

The general contractor has been hired by the property owner as the general contractor for the project; and

(6). The general contractor must purchase an electrical work permit for the temporary service, request inspection, and obtain approval prior to energizing the service.

D.. Conformance. Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this chapter and the technical codes as necessary to ensure the public health, safety and general welfare.

E. Termination of Approval. The building official is authorized to terminate any temporary permit issued under this section and to order the activity, use or structure authorized under the permit to be discontinued.

Section 6. Section 23.05.130 of the Bellevue City Code is hereby amended to read as follows:

### **23.05.130 Inspections.**

A. General. Construction or work for which a permit is required shall be subject to inspection by the building official and such construction or work shall remain

accessible and exposed for inspection purposes until approved. Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of this chapter, the technical codes, or of other ordinances of the city. Inspections presuming to give authority to violate or cancel the provisions of this chapter, the technical codes, or of other ordinances of the city shall not be valid. It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the building official nor the city shall be liable for expense entailed in the removal or replacement of any material required to allow inspection. When the installation of an electrical system is complete, an additional and final inspection shall be made. Electrical systems and equipment regulated by the National Electrical Code shall not be connected to the energy source until authorized by the building official.

B. Preliminary Inspections. Before issuing a permit, the building official is authorized to examine or cause to be examined buildings, structures and sites for which an application has been filed.

C. Required Inspections. The building official, upon notification, shall make the following inspections:

1. Footing and Foundation Inspection. Footing and foundation inspections shall be made after excavations for footings are complete and any required reinforcing steel is in place. For concrete foundations, any required forms shall be in place prior to inspection. Materials for the foundation shall be on the job, except where concrete is ready-mixed in accordance with ASTM C 94, the concrete need not be on the job.

2. Electrical Underground. Underground inspection shall be made after trenches or ditches are excavated and bedded, piping and conductors are installed, and before backfill is installed. Where excavated soil contains rocks, broken concrete, frozen chunks and other rubble that would damage or break the raceway, cable or conductors, or where corrosive action will occur, protection shall be provided in the form of granular or selected material, approved running boards, sleeves or other means.

3. Concrete Slab and Under-Floor Inspection. Concrete slab and under-floor inspections shall be made after in-slab or under-floor reinforcing steel and building service equipment, conduit, slab insulation, piping accessories and other ancillary equipment items are in place, but before any concrete is placed or floor sheathing installed, including the subfloor.

4. Lowest Floor Elevation. In flood hazard areas, upon placement of the lowest floor, including the basement, and prior to further vertical construction, the elevation certification required in IBC Section 1612.5 or IRC Section R323 shall be submitted to the building official.

5. Exterior Wall Sheathing Inspection. Exterior wall sheathing shall be inspected after all wall framing is complete, strapping and nailing is properly installed but prior to being covered.

6. Roof Sheathing Inspection. Roof sheathing shall be inspected after all roof framing is complete. No roof coverings shall be installed until inspections are made and approved.

7. IMC/UPC/GAS/NEC Rough-in Inspection. Rough-in mechanical, gas piping, plumbing and electrical shall be inspected when the rough-in work is

complete and, if required, under test. No connections to primary utilities shall be made until the rough-in work is inspected and approved. Electrical rough-in inspection shall be made after the roof, framing, fireblocking and bracing are in place and all wiring and other components to be concealed are complete, and prior to the installation of wall or ceiling membranes. All required equipment grounding conductors installed in concealed cable or flexible conduit systems must be completely installed and made up at the time of the rough-in cover inspection.

**87. Frame Inspection.** Framing inspections shall be made after the roof deck or sheathing, all framing, fire blocking and bracing are in place and pipes, chimneys and vents to be concealed are complete and the rough electrical, plumbing, heating wires, pipes and ducts are approved.

**98. Lath Inspection and Gypsum Board Inspection.** Lath and gypsum board inspections shall be made after lathing and gypsum board, interior and exterior, are in place, but before any plastering is applied or gypsum board joints and fasteners are taped and finished.

Exception: Gypsum board that is not part of a fire-resistance rated assembly or a shear assembly.

**109. Fire-Resistant Penetration Inspections.** Protection of joints and penetrations in fire-resistance-rated assemblies shall not be concealed from view until inspected and approved.

**110. Energy Efficiency Inspection.**

a. Envelope.

i. Wall Insulation Inspection. To be made after all wall insulation and air vapor retarder sheet or film materials are in place, but before any wall covering is placed.

ii. Glazing Inspection. To be made after glazing materials are installed in the building.

iii. Exterior Roofing Insulation. To be made after the installation of the roof insulation, but before concealment.

iv. Slab/Floor Insulation. To be made after the installation of the slab/floor insulation, but before concealment.

b. Mechanical.

i. Mechanical Equipment Efficiency and Economizer. To be made after all equipment and controls required by this chapter and the technical codes are installed and prior to the concealment of such equipment or controls.

ii. Mechanical Pipe and Duct Insulation. To be made after all pipe and duct insulation is in place, but before concealment.

c. Lighting and Motors.

i. Lighting Equipment and Controls. To be made after the installation of all lighting equipment and controls required by this chapter and the technical codes, but before concealment of the lighting equipment.

ii. Motor Inspections. To be made after installation of all equipment covered by the Energy Code, but before concealment.

**12. Electrical.** The building official may require special inspection of equipment or wiring methods under the following conditions:

a. Where the installation requires special training, equipment, expertise, or knowledge;

. Where there is insufficient evidence of compliance with the provisions of this code;

c. Where the material or method does not conform to the requirements of this code; or

d. To substantiate claims for alternative materials or methods.

Where such special inspection is required, it shall be performed by an accredited electrical products testing laboratory approved by the State of Washington under WAC 296-46B-999 and acceptable to the building official. The special inspection person/agency shall be designated and approved prior to beginning the installation of wiring or equipment. A written report from the designated special inspection agency indicating that the installation conforms to the appropriate codes and standards shall be received by the building official prior to that installation being approved. All costs for such testing and reporting shall be the responsibility of the permit holder.

13. Final Inspection. The final inspection shall be made after all work required by the permit is completed.

Section 7. Section 23.05.190 of the Bellevue City Code is hereby amended to read as follows:

**23.05.190 Unsafe structures and equipment.**

A. Buildings or structures regulated by this chapter and the technical codes which are structurally inadequate or have inadequate egress, or which constitute a fire hazard, or are otherwise dangerous to human life are, for the purpose of this section, unsafe buildings.

B. Building service equipment regulated by such codes, which constitutes a fire, electrical or health hazard, or an unsanitary condition, or which is otherwise dangerous to human life is, for the purpose of this section, unsafe. Use of buildings, structures or building service equipment constituting a hazard to safety, health or public welfare by reason of inadequate maintenance, dilapidation, obsolescence, fire hazard, disaster, damage or abandonment is, for the purpose of this section, an unsafe use.

C. Parapet walls, cornices, spires, towers, tanks, statuary and other appendages or structural members which are supported by, attached to, or otherwise unable to sustain the design loads which are specified in the building code are designated as unsafe building appendages.

D. Unsafe buildings, structures or appendages and building service equipment are declared to be public nuisances and shall be abated by repair, rehabilitation, demolition or removal in accordance with the procedures set forth in the dangerous buildings code or such alternative procedure as may be adopted by the city. As an alternative, the building official or other employee or official of the city as designated by the governing body may institute other appropriate action to prevent, restrain, correct or abate the violation.

E. Authority to condemn electrical systems. Wherever the Building official determines that any electrical system, or portion thereof, regulated by this code

has become hazardous to life, health or property, the building official shall order in writing that such electrical systems either be removed or restored to a safe condition. A time limit for compliance with such order shall be specified in the written notice. A person shall not use or maintain a defective electrical system or equipment after receiving such notice. Where such electrical system is to be disconnected, written notice as prescribed in this code shall be given. In cases of immediate danger to life or property, such disconnection shall be made immediately without such notice.

F. Connection after order to disconnect. A person shall not make utility service or energy source connections to systems regulated by this code, which have been disconnected or ordered to be disconnected or the use of which has been ordered to be discontinued by the building official, until the building official authorizes the reconnection and use of such systems.

Section 8. If any section, subsection, paragraph, sentence, clause, or phrase of this ordinance is declared unconstitutional or invalid for any reason, such decision shall not affect the validity of the remaining parts of this ordinance.

Section 9. This ordinance shall take effect and be in force thirty (30) days after passage and legal publication.

Passed by the City Council this \_\_\_\_\_ day of \_\_\_\_\_, 2010  
and signed in authentication of its passage this \_\_\_\_\_ day of \_\_\_\_\_,  
2010.

(SEAL)

\_\_\_\_\_  
Don Davidson, Mayor

Approved as to form:

Lori M. Riordan, City Attorney

\_\_\_\_\_  
Lacey Madche, Assistant City Attorney

Attest:

\_\_\_\_\_  
Myrna L. Basich, City Clerk

-ORD  
01/05/10

Published \_\_\_\_\_


DRAFT



Washington Association  
of Building Officials

# The Washington Cities Electrical Code

November 12, 2009



## PREFACE

### Introduction

The Washington Cities Electrical Code is a joint effort between the MyBuildingPermit.com (MBP) EGov portal and the Washington Association of Building Officials (WABO). This Code was created to provide cities with a document that complies with RCW 19.28.010(3), which allows cities to enforce any Ordinance that is equal, higher or better than the State's rules, but offers the following advantages.

- This Code omits all administrative and procedural State rules that cities cannot or choose not to adopt.
- This Code is written in the same format as the NEC to eliminate any conflict between a State rule and the NEC. This format will also allow the creation of insert pages that can be inserted into the applicable pages of the NEC.
- This Code provides enforcement consistency among those cities that choose to adopt it.

### Development

The partnership between MBP and WABO resulted in an Electrical Committee open to any Washington city and county wishing to participate. The Electrical Committee had participation from Bellevue, Bellingham, Burien, Des Moines, Kirkland, King County, Lacey, Longview, Marysville, Mercer Island, Olympia, Redmond, Renton, SeaTac, Seattle and Vancouver. The committee compared the 2008 NEC to the most current State rules and to any regional concerns and through consensus produced this Code. All Washington cities are encouraged to adopt this Code.

### MyBuildingPermit.com

MyBuildingPermit.com (MBP) is an internet portal currently shared by 16 cities and one county. Through the MBP portal, homeowners and contractors can obtain over the counter types of electrical, plumbing, mechanical and reroof permits. Plans are under way to allow the submittal of plans electronically through the MBP site.

Other services provided through the MBP site include:

- Online inspection requests
- Current permit status

- Tip sheets for various construction issues
- Training opportunities

The member jurisdictions are dedicated to providing a consistent and efficient permitting experience to their customers. The current members of MBP are, Bellevue, Bothell, Burien, Duvall, Gig Harbor, Kenmore, Kirkland, Issaquah, Mercer Island, Mill Creek, Mukilteo, Renton, Sammamish, SeaTac, Snohomish County, Snoqualmie, Woodinville .

### **Washington Association of Building Officials**

The Washington Association of Building Officials (WABO) was incorporated in 1977 to promote building codes and standards that safeguard the public health and safety; advise on legislative matters; assist in the development of national and state codes; provide educational opportunities for its members; and preserve local government control of code administration.

The WABO is a nonprofit, professional association of state, county, city and town officials in Washington State engaged in the development, enforcement and administration of building construction codes and ordinances. Members (both governmental and associate) are building officials and inspectors, planners, architects, structural engineers and others interested in providing safe buildings for our communities.

### **Format**

This Code is divided into three parts to facilitate those cities that do not want to adopt the entire document. Part 1 adopts the 2008 NEC and other necessary codes and standards adopted by the State. Part 2 is an administrative chapter based on portions of the ICC Electrical Code, published by the International Code Council. It provides necessary rules for enforcing and administering the NEC. Part 3 amends the NEC through supplements, deletions or revisions to be equal, higher or better than the State's rules. Only those Sections of the NEC that have been amended are included in this Code.

## Table of Contents

### Part 1 Adoption

Short Title.....	6
National Electrical Code and Standards Adopted.....	6
Conflicts.....	6

### Part 2 Administration

Purpose.....	7
Scope.....	7
Applicability.....	8
Moved Buildings.....	10
Organization and Enforcement.....	12
Permits and Fees.....	14
Construction Documents.....	19
Approval.....	24
Inspections and Testing.....	26
Service Utilities.....	30
Unsafe Systems and Equipment.....	31
Violations.....	32
Appeals.....	34
Additional Electrical provisions.....	34

### Part 3 NEC Amendments

Article 90.7	Examination of equipment for safety.....	38
Article 100	Definitions.....	38
Article 110.2	Approval.....	46
Article 110.3	Examination, Identification, Installation, and Use of Equipment.....	46
Article 110.12	Mechanical Execution of Work.....	47
Article 110.16	Flash protection.....	48
Article 110.22	Identification of Disconnecting Means.....	49
Article 200.6	Means of Identifying Grounder Conductors.....	49
Article 210.8	Ground Fault Circuit-Interrupter Protection for Personnel.....	50
Article 210.11	Branch Circuits Required.....	50
Article 210.12	Arc-Fault Circuit-Interrupter Protection.....	51
Article 215.10	Ground-Fault Protection of Equipment.....	51
Article 220.12	Lighting Loads for Specified occupancies.....	51
Article 220.87	Optional Calculations for Determining Existing Loads.....	52
Article 225.30	Number of Supplies.....	52
Article 225.32	Location.....	52
Article 230.28	Service Mast Supports.....	53
Article 230.43	Wiring Methods for 60 Volts, Nominal, or Less.....	58
Article 230.70	Service Equipment – Disconnecting Means – General.....	58
Article 230.90	Service Equipment – Overcurrent Protection.....	59

Article 230.95	Ground-Fault Protection of Equipment.....	59
Article 230.202	Service-Entrance Conductors.....	60
Article 240.24	Location on Premises – Not located over a step.....	60
Article 250.28	Main Bonding Jumper and System Bonding Jumper.....	60
Article 250.50	Grounding Electrode System.....	61
Article 250.56	Resistance of Rod, Plate and Pipe Electrodes.....	61
Article 250.68	Grounding Electrode Conductor and Bonding Jumper Connections.....	61
Article 250.104	Bonding of Piping Systems and Exposed Structural Steel.....	61
Article 250.184	Solidly Grounded Neutral Systems.....	62
Article 300.11	Securing and Supporting.....	63
Article 310.12	Conductor Identification.....	64
Article 314.23	Supports.....	65
Article 334.15	Exposed Work.....	66
Article 358.10	Electrical Metallic Tubing: Type EMT - Wet Locations.....	66
Article 358.12	Electrical Metallic Tubing: Type EMT - Uses Not Permitted.....	66
Article 394.12	Concealed Knob-and-Tube Wiring - Uses Not Permitted.....	66
Article 406.15	Tamper Resistant Receptacles.....	67
Article 410.10	Bathtub and Shower Areas.....	67
Article 410.62	Cord-Connected Lampholders and Luminaires.....	68
Article 422.10	Branch-Circuit Rating.....	68
Article 445.20	Generators.....	68
Article 450.27	Oil-Insulated Transformers Installed Outdoors.....	69
Article 450.42	Walls, Roofs, and Floors.....	70
Article 501.200	Sewage Disposal Systems.....	70
Article 514.11	Circuit Disconnects.....	71
Article 517.29	Health Care Facilities - General Requirements.....	72
Article 519	Education and Institutional Occupancies.....	73
Article 525.1	Carnivals, Circuses, Fairs, and Similar Events – Scope.....	74
Article 547.1	Agricultural Buildings – Scope.....	74
Article 553.4	Location of Service Equipment.....	74
Article 553.6	Feeder Conductors.....	74
Article 553.7	Installation of Services and Feeders.....	75
Article 555.1	Marinas and Boatyards – Scope.....	75
Article 555.5	Transformers.....	75
Article 555.7	Location of Service Equipment.....	75
Article 555.9	Electrical Connections.....	75
Article 555.10	Electrical Equipment Enclosures.....	76
Article 555.13	Wiring Methods and Installation.....	76
Article 555.19	Receptacles.....	76
Article 555.21	Gasoline Dispensing Stations – Hazardous Locations.....	76
Article 590.1	Temporary Installations – Scope.....	77
Article 590.4	General – Splices.....	77
Article 600.3	Electrical Signs and Outline Lighting – Listing.....	77
Article 600.10	Portable or Mobile Signs.....	77
Article 600.21	Ballasts, Transformers, and Electronic Power Supplies.....	78
Article 680.4	Approval of Equipment.....	78
Article 680.13	Field Installed Equipment.....	79
Article 680.25	Feeders.....	79

Article 680.40	Spas and Hot Tubs – General.....	80
Article 680.70	Hydromassage Bathtubs – General.....	80
Article 690.2	Solar Photovoltaic Systems – Definitions.....	80
Article 690.4	Solar Photovoltaic Systems – Installations.....	81
Article 690.7	Solar Photovoltaic Systems – Maximum Voltage.....	81
Article 700.6	Emergency Systems - Transfer Equipment.....	81
Article 700.8	Emergency Systems – Signs.....	82
Article 700.9	Wiring Emergency Systems.....	82
Article 700.12	Emergency Systems – Sources of Power.....	83
Article 700.27	Coordination.....	84
Article 700.30	Smoke Control Systems - Pressurization Wiring and Equipment.....	85
Article 701.7	Transfer Equipment.....	85
Article 701.9	Legally Required Standby Systems – Signs.....	86
Article 701.11	Legally Required Standby Systems.....	86
Article 701.18	Coordination.....	85
Article 702.8	Optional Standby Systems – Signs.....	86
Article 725.3	Class 1, Class 2, and Class 3 Circuits - Other Articles.....	86
Article 760.3	Other articles – Suspended Ceilings.....	86
Article 760.12	amended – Fire Alarm Systems.....	87
Article 760.30	Fire Alarm Circuit Identification.....	87
Article 770.3	Optical Fiber Cables and Raceways – Other Articles.....	88
Article 800.3	Communication Circuits – Other Articles.....	88
Article 800.30	Communication Circuits – Network Demarcation Point.....	88

# Part 1 - Adoption

## **80 National Electrical Code Article 80 created — Adoption.**

The National Electrical Code is amended and supplemented by the addition of a new Article to be known as Article 80 – Adoption, to read as follows:

### **Article 80 Adoption**

**80.1 Short Title.** These regulations shall be known as the City Electrical Code and shall be cited as such and will be referred to herein as “this code.”

**80.3 National Electrical Code and Standards Adopted.** The 2008 Edition of the National Electrical Code (NFPA 70), including Annex A, B and C; the 2007 Edition of Standard for the Installation of Stationary Pumps for Fire Protection (NFPA 20-2007); the 2005 Edition of Standard for Emergency and Standby Power Systems (NFPA 110-2005); Commercial Building Telecommunications Cabling Standard (ANSI/TIA/EIA 568-B.1 June 2002 including Annex 1 through 5); Commercial Building Standard for Telecommunications Pathway and Spaces (ANSI/TIA/EIA 569-A-7 December 2001 including Annex 1 through 4); Commercial Building Grounding and Bonding Requirements for Telecommunications (ANSI/ TIA/EIA 607-A-2002); and the Residential Telecommunications Cable Standard (ANSI/TIA/EIA 570-B-2004) are adopted and shall be applicable within the city, as amended, added to and excepted in this code.

**80.4 Conflicts.** In accordance with RCW 19.28.010(3), where the State of Washington, Department of Labor and Industries adopts a more current edition of the National Electrical Code (NFPA 70) the Code Official may supplement use of this Code with newly adopted editions of the National Electrical Code.

## Part 2 - Administration

### **85 National Electrical Code Article 85 created — Administration.**

The National Electrical Code is amended and supplemented by the addition of a new Article to be known as Article 85 – Administration, to read as follows:

#### **Article 85 Administration**

**85.1 Purpose.** The purpose of this code is to provide minimum standards to safeguard life or limb, health, property and public welfare by regulating and controlling the design, construction, installation, quality of materials, location, operation, and maintenance or use of electrical systems and equipment.

**85.3 Scope.** This code covers the installation of electric conductors, electric equipment and additions, alterations, modifications, or repairs to existing electrical installations for the following:

- (A) Electric conductors, electric equipment, and electrical raceways installed within or on public and private buildings, property or other structures.
- (B) Signaling and communications conductors and equipment, telecommunications conductors and equipment, fiber optic cables, and raceways installed within or on public and private buildings, property or other structures.
- (C) Yards, lots, parking lots, and industrial substations.
- (D) Temporary electrical installations for use during the construction of buildings.
- (E) Temporary electrical installations for carnivals, conventions, festivals, fairs, traveling shows, the holding of religious services, temporary lighting of streets, or other approved uses.
- (F) Installations of conductors and equipment that connect to a supply of electricity.
- (G) All other outside electrical conductors on the premises.
- (H) Optional standby systems derived from portable generators.

*Exception: Installations under the exclusive control of electric utilities for the purpose of communication, transmission, and distribution of electric energy located in buildings used exclusively by utilities for such purposes*

*or located outdoors on property owned or leased by the utilities or on public highways, streets, roads, etc., or outdoors by established rights on private property.*

It is the intent of this section that this code covers all premises' wiring or wiring other than utility owned metering equipment, on the load side of the service point of buildings, structures, or any other premises not owned or leased by the utility. Also, it is the intent that this code covers installations in buildings used by the utility for purposes other than listed in above, such as offices buildings, warehouses, garages, machine shops, and recreational buildings which are not an integral part of a generating plant, substation, or control center.

### **85.5 Applicability**

**(A) New Installations.** This code applies to new electrical installations. Exception: If an electrical permit application is received after this chapter has taken effect, but is associated with a building permit application received prior to the effective date of the ordinance codified in this chapter, all applicable codes adopted and in force at the time of a complete building permit application will apply.

**(B) Existing installations.** Lawfully installed existing electrical installations that do not comply with the provisions of this chapter shall be permitted to be continued without change, except as is specifically covered in this code, the International Fire Code or as is deemed necessary by the building official for the general safety and welfare of the occupants and the public. Where changes are required for correction of hazards, a reasonable amount of time shall be given for compliance, depending on the degree of the hazard.

**(C) Maintenance.** Electrical systems, equipment, materials and appurtenances, both existing and new, and parts thereof shall be maintained in proper operating condition in accordance with the original design and in a safe, hazard-free condition. Devices or safeguards that are required by this code shall be maintained in compliance with the code edition under which installed. The owner or the owner's designated agent shall be responsible for the maintenance of the electrical systems and equipment. To determine compliance with this provision, the code official shall have the authority to require that the electrical systems and equipment be re-inspected.

**(D) Additions, alterations, modifications or repairs.** Additions, alterations, modifications or repairs to the electrical system of any building,

structure, or premises shall conform to the requirements of this code without requiring those portions of the existing building not being altered or modified to comply with all the requirements of this code. Installations, additions, alterations, modifications, or repairs shall not cause an existing building to become unsafe or to adversely affect the performance of the building as determined by the building official or designated representative. Electrical wiring added to an existing service, feeder, or branch circuit shall not result in an installation that violates the provisions of the code in force at the time the additions were made.

**(E) Change in occupancy.** It shall be unlawful to make a change in the occupancy of any structure that will subject the structure to any special provision of this code applicable to the new occupancy without approval. The code official shall certify that such structure meets the intent of the provisions of law governing building construction for the proposed new occupancy and that such change of occupancy does not result in any hazard to public health, safety or welfare.

**(F) Differences.**

(1) Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall be applicable.

(2) The requirements of this code will be observed where there is any conflict between this code and the National Electrical Code (NFPA 70), Centrifugal Fire Pumps (NFPA 20), the Emergency and Standby Power Systems (NFPA 110), ANSI/TIA/EIA 568-B, ANSI/TIA/EIA 569-A, ANSI/TIA/EIA 607, or ANSI/TIA/EIA 570..

(3) The National Electrical Code will be followed where there is any conflict between standard for Installation of Stationary Pumps for Fire Protection (NFPA 20), standard for Emergency and Standby Power Systems (NFPA 110), ANSI/TIA/EIA 568-B, ANSI/TIA/EIA 569-A, ANSI/TIA/EIA 607, ANSI/TIA/EIA 570-B, and the National Electrical Code (NFPA 70).

**(G) Other laws.** The provisions of this code shall not be deemed to nullify any provisions of local, state or federal law.

**(H) Validity.** In the event any part or provision of this code is held to be illegal or void, this shall not have the effect of making void or illegal any of the other parts or provisions thereof, which are determined to be legal; and it shall be presumed that this code would have been adopted without such illegal or invalid parts or provisions.

**(I) Segregation of invalid provisions.** Any invalid part of this code shall be segregated from the remainder of this code by the court holding such part invalid, and the remainder shall remain effective.

**(J) Application of references.** References to chapter or section numbers, or to provisions not specifically identified by number, shall be construed to refer to such chapters, sections or provisions of this code.

**(K) Referenced codes and standards.** The codes and standards referenced in this code shall be considered part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between provisions of this code and referenced codes or standards, the provisions of this code shall apply.

*Exception: Where enforcement of a code provision would violate the conditions of the listing of the equipment or appliance, the conditions of the listing and manufacturer's instructions shall apply.*

**(L) Annex Chapters** Provisions in the annex chapters shall not apply unless specifically referenced in the adopting ordinance.

**(M) Subjects not regulated by this code.** Where no applicable standards or requirements are set forth in this code, or are contained within other laws, codes, regulations, ordinances or bylaws adopted by the jurisdiction, compliance with applicable standards of nationally recognized standards as are approved shall be deemed as prima facie evidence of compliance with the intent of this code. Nothing herein shall derogate from the authority of the code official to determine compliance with codes or standards for those activities or installations within the code official's jurisdiction or responsibility.

### **85.9 Moved buildings or structures.**

**(A)** Buildings or structures intended to be relocated within or into the city must be inspected by the code official for compliance with the codes and standards adopted in this chapter prior to being relocated or moved. The owner of the building or structure must obtain a building permit and further must agree to correct all deficiencies identified by the inspection prior to moving the building. All deficiencies must be corrected before electric power is connected to the building.

**(B)** Nonresidential buildings or structures moved into the jurisdiction must be inspected to ensure compliance with current requirements of this Code.

**(C)** Residential buildings or structures wired in the U.S., to NEC requirements, and moved into the jurisdiction must be inspected to ensure compliance with the NEC requirements in effect at the time and place the original wiring was made. The building or structure must be inspected to

ensure compliance with all current requirements of chapter 19.28 RCW and the rules developed by the department if:

- (1) The original occupancy classification of the building or structure is changed as a result of the move; or
- (2) The building or structure has been substantially remodeled or rehabilitated as a result of the move.

**(D)** Residential buildings or structures wired in Canada to Canadian Electrical Code (CEC) standards and moved into the jurisdiction must be inspected to ensure compliance with the following minimum safety requirements:

- (1) Service, service grounding, and service bonding must comply with this Code.
- (2) Canadian Standards Association (CSA) listed Type NMD cable is allowed with the following qualifications:
  - (a) CSA listed Type NMD cable, American Wire Gauge #10 and smaller installed after 1964 utilizing an equipment grounding conductor smaller than the phase conductors, must be:
    - (i) Replaced with a cable utilizing a full-size equipment grounding conductor; or
    - (ii) Protected by a ground fault circuit interrupter protection device.
  - (b) CSA listed Type NMD cable, #8 AWG and larger, must:
    - (i) Utilize an equipment grounding conductor sized according to the requirements of the NEC in effect at the time of the installation;
    - (ii) Be protected by a ground fault circuit interrupter protection device; or
    - (iii) Be replaced.
- (3) Other types of wiring and cable must be:
  - (a) Replaced with wiring listed or field evaluated in accordance with U.S. standards by a laboratory approved by the department; or
  - (b) Protected by a ground fault circuit interrupter protection device and arc fault circuit protection device.
- (4) Equipment, other than wiring or panelboards, manufactured and installed prior to 1997 must be listed and identified by laboratory labels approved by the department or CSA labels.
- (5) All panelboards must be listed and identified by testing laboratory labels approved by the department with the following qualifications:
  - (a) CSA listed panelboards labeled "Suitable for Use as Service Equipment" will be considered to be approved as "Suitable for Use only as Service Equipment."
  - (b) CSA listed panelboards must be limited to a maximum of 42 circuits.

- (c) CSA listed panelboards used as lighting and appliance panelboards as described in the NEC, must meet all current requirements of the NEC and this chapter.
- (6) Any wiring or panelboards replaced or changed as a result of the move must meet current requirements of chapter 19.28 RCW and this chapter.
- (7) The location, type, and ground fault circuit interrupter protection of receptacles and equipment in a bathroom, kitchen, basement, garage, or outdoor area must meet the Washington requirements in effect at the time the wiring was installed.
- (8) 4, 15-ampere, kitchen small appliance circuits will be accepted in lieu of 2, 20-ampere, kitchen small appliance circuits. Receptacles will not be required to be added on kitchen peninsular or island counters.
- (9) Spacing requirements for all other receptacles must meet the Washington requirements in effect at the time the wiring was installed.
- (10) Receptacles installed above baseboard or fixed wall space heaters must be removed and the outlet box covered with a blank cover. The receptacle is required to be relocated as closely as possible to the existing location.
- (11) Lighting outlet and switch locations must meet the Washington requirements in effect at the time the wiring was installed.
- (12) Dedicated 20-ampere small appliance circuits are not required in dining rooms.
- (13) Electric water heater branch circuits must be adequate for the load.
- (14) The location, type, and circuit protection of feeders must meet the Washington State requirements in effect at the time the wiring was installed.

### **85.11 Organization and Enforcement**

**(A) Creation of enforcement agency.** The department of electrical inspection is hereby created and the official in charge thereof shall be known as the code official. The function of the department shall be to assist the code official in the administration and enforcement of the provisions of this code.

**(B) Appointment.** The code official shall be appointed by the chief appointing authority of the jurisdiction.

**(C) Deputies.** In accordance with the prescribed procedures of this jurisdiction and with the concurrence of the appointing authority, the code official shall have the authority to appoint a deputy code official, the related technical officers, inspectors, plans examiners and other employees. Such employees shall have powers as delegated by the code official.

**(D) Duties and powers of the code official.** The code official is hereby authorized and directed to enforce the provisions of this code. The code official shall have the authority to render interpretations of this code, and to adopt policies, procedures, rules and regulations in order to clarify the application of its provisions. Such interpretations, policies, procedures, rules and regulations shall be in compliance with the intent and purpose of this code. Such policies and procedures shall not have the effect of waiving requirements specifically provided for in this code.

**(1) Rule-making authority.** The code official shall have authority as necessary in the interest of public health, safety and general welfare, to adopt and promulgate rules and regulations and to designate requirements applicable because of local climatic or other conditions. Such rules shall not have the effect of waiving requirements specifically provided for in this code, or of violating accepted engineering methods involving public safety.

**(2) Applications and permits.** The code official is authorized to receive applications, review construction documents and issue permits for the installation of electrical systems and equipment, inspect the premises for which such permits have been issued, and enforce compliance with the provisions of this code.

**(3) Notices and orders.** The code official is authorized to issue all necessary notices or orders in accordance with Section 85.25(B) as are required to effect compliance with this code.

**(4) Inspections.** The code official shall make all of the inspections necessary to determine compliance with the provisions of this code in accordance with Section 85.19.

**(5) Identification.** The code official shall carry proper identification as required by Section 85.19(G).

**(6) Right of entry.** The code official is authorized to enter the structure or premises at reasonable times to inspect or perform the duties imposed by this code in accordance with Section 85.19(I).

**(7) Department records.** The code official shall keep official records of applications received, permits and certificates issued, fees collected, reports of inspections, notices and orders issued, and as required by this code, such records shall be retained in the official records for the period required for retention of public records.

**(8) Approvals and modifications.** A record of approvals and modifications granted shall be maintained by the code official and shall be available for public inspection during business hours in accordance with applicable laws.

**(9) Inspections.** The code official shall keep a record of each inspection made, including notices and orders issued, showing the findings and disposition of each.

**(10) Alternative methods or materials.** The application for modification, alternative methods or materials and the final decision of the code official shall be in writing and shall be officially recorded in the permanent records of the code official.

**(11) Liability.** The code official, officer or employee charged with the enforcement of this code, while acting for the jurisdiction in good faith and without malice in the discharge of the duties required by this code or other pertinent law or ordinance, shall not thereby be rendered liable personally, and is hereby relieved from all personal liability for any damage accruing to persons or property as a result of any act or by reason of an act or omission in the discharge of official duties. Any suit instituted against any officer or employee because of an act performed by that officer or employee in the lawful discharge of duties and under the provisions of this code shall be defended by the legal representative of the jurisdiction until the final termination of the proceedings.

The code official or any subordinate shall not be liable for costs in any action, suit or proceeding that is instituted in pursuance of the provisions of this code; and any official, officer or employee, acting in good faith and without malice, shall be free from liability for acts performed under any of its provisions or by reason of any act or omission in the performance of official duties in connection therewith.

**(E) Certificate of Occupancy.** No building or structure shall be used or occupied until a certificate of occupancy has been provided in accordance with the *International Building Code*.

### **85.13 Permits and Fees.**

**(A) Permits required.** Permits required by this code shall be obtained from the code official. Permit fees, if any, shall be paid prior to issuance of the permit. Issued permits shall be kept on the premises designated therein at all times and shall be readily available for inspection by the code official.

**(B) Types of permits.** An owner, authorized agent or contractor who desires to construct, enlarge, alter, repair, move, demolish or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace electrical systems or equipment, the installation of which is regulated by this code, or to cause such work to be done, shall first make application to the code official and obtain the required permit for the work.

*Exception: Where repair or replacement of electrical systems or equipment must be performed in an emergency situation, the permit application shall be submitted within the next working business day.*

**(C) Telecommunication Systems.** An electrical permit is required for all installations of telecommunications systems on the customer side of the network demarcation point for projects greater than ten telecommunications outlets. All backbone installations regardless of size and all telecommunications cable or equipment installations involving penetrations of fire barriers or passing through hazardous locations require permits and inspections. For the purposes of determining the inspection threshold for telecommunications projects greater than ten outlets, the following will apply:

- (1) An outlet is the combination of jacks and mounting hardware for those jacks, along with the associated cable and telecommunications closet terminations that serve one workstation. In counting outlets to determine the inspection threshold, one outlet must not be associated with more than six standard four pair cables or more than one twenty-five-pair cable. Therefore, installations of greater than sixty standard four-pair cables or ten standard twenty-five-pair cables require permits and inspections. (It is not the intent of the statute to allow large masses of cables to be run to workstations or spaces serving telecommunications equipment without inspection. Proper cable support and proper loading of building structural elements are safety concerns. When considering total associated cables, the telecommunications availability at one workstation may count as more than one outlet.)
- (2) The installation of greater than ten outlets and the associated cables along any horizontal pathway from a telecommunications closet to work areas during any continuous ninety-day period requires a permit and inspection.
- (3) All telecommunications installations within the residential dwelling units of single-family, duplex, and multifamily dwellings do not require permits or inspections. In residential multifamily dwellings, permits and inspections are required for all backbone installations, all fire barrier penetrations, and installations of greater than ten outlets in common areas.
- (4) No permits or inspections are required for installation or replacement of cord and plug connected telecommunications equipment or for patch cord and jumper cross-connected equipment.
- (5) Definitions of telecommunications technical terms will come from chapter 19.28 RCW, this chapter, TIA/EIA standards, and NEC.

**(D) Temporary Installations.** For temporary electrical installations, the city will consider a permit applicant to be the owner per RCW 19.28.261 under the conditions below:

Any person firm, partnership, corporation, or other entity registered as a general contractor under chapter 18.27 RCW will be permitted to install a single electrical service per address for the purposes of temporary power during the construction phase of a project, when all of the following conditions are met:

- 1) The installation is limited to the mounting and bracing of a pre-assembled pole or pedestal mounted service, the installation of a ground rod or ground plate, and the connection of the grounding electrode conductor to the ground rod or plate;
- 2) The total service size does not exceed 200 amperes, 250 volts nominal;
- 3) The service supplies no feeders;
- 4) Branch circuits not exceeding 50 amperes each are permitted, provided such branch circuits supply only receptacles that are either part of the service equipment or are mounted on the same pole;
- 5) The general contractor owns the electrical equipment;
- 6) The general contractor has been hired by the property owner as the general contractor for the project;
- 7) The general contractor must purchase an electrical work permit for the temporary service, request inspection, and obtain approval prior to energizing the service.

**(E) Work exempt from permit.**

As required by chapter 19.28 RCW or this chapter, an electrical permit is required for the installation, alteration, or maintenance of all electrical systems or equipment except for:

- (1) Travel trailers;
- (2) Basic electrical work which includes:
  - a) The like-in-kind replacement of a: Contactor, relay, timer, starter, circuit board, or similar control component; household appliance; circuit breaker; fuse; residential luminaire; lamp; snap switch; dimmer; receptacle outlet; thermostat; heating element; luminaire ballast with an exact same ballast; component(s) of electric signs, outline lighting, skeleton neon tubing when replaced on-site by an appropriate electrical contractor and when the sign, outline lighting or skeleton neon tubing electrical system is not modified; ten horsepower or smaller motor;
  - b) Induction detection loops described in WAC 296-46B-300(2) and used to control gate access devices; and
  - c) Heat cable repair

Unless specifically noted, the exemptions listed do not include: The replacement of an equipment unit, assembly, or enclosure that contains an exempted component or combination of components. (i.e., electrical furnace/heat pumps, industrial milling machine, etc.)

Exemption from the permit requirements of this code shall not be deemed to grant authorization for work to be done in violation of the provisions of this code or other laws or ordinances of this jurisdiction.

**(F) Application.** Application for a permit required by this code shall be made to the code official in such form and detail as prescribed by the code official. Applications for permits shall be accompanied by such plans as prescribed by the code official.

**(1) Action on application.** The code official shall examine or cause to be examined applications for permits and amendments thereto within a reasonable time after filing. If the application or the construction documents do not conform to the requirements of pertinent laws, the code official shall reject such application in writing, stating the reasons therefore. If the code official is satisfied that the proposed work conforms to the requirements of this code and laws and ordinances applicable thereto, the code official shall issue a permit as soon as practicable.

**(2) Inspection required.** Before a permit is issued, the code official is authorized to inspect and approve the systems, equipment, buildings, devices, premises and spaces or areas to be used.

**(3) Time limitation of application.** An application for a permit for any proposed work or operation shall be deemed to have been abandoned 180 days after the date of filing, unless such application has been pursued in good faith or a permit has been issued; except that the code official is authorized to grant one extension of time for an additional period not exceeding 90 days. The extension shall be requested in writing and justifiable cause demonstrated.

**(G) Conditions of a permit.** A permit shall constitute permission to conduct work as set forth in this code in accordance with the provisions of this code. Such permission shall not be construed as authority to violate, cancel or set aside any of the provisions of this code or other applicable regulations or laws of the jurisdiction.

**(H) Expiration.** Every permit issued shall become invalid unless the work on the site authorized by such permit is commenced within 180 days after its issuance, or if the work authorized on the site by such permit is suspended or abandoned for a period of 180 days after the time the work is commenced. The code official is authorized to grant, in writing, one or more

extensions of time, for periods not more than 180 days each. The extension shall be requested in writing and justifiable cause demonstrated.

**(I) Extensions.** The code official is authorized to grant, in writing, one or more extensions of the time period of a permit for periods of not more than 90 days each. Such extensions shall be requested by the permit holder in writing and justifiable cause demonstrated.

**(J) Posting the permit.** Issued permits shall be kept on the premises designated therein at all times and shall be readily available for inspection by the code official.

**(K) Validity.** The issuance or granting of a permit shall not be construed to be a permit for, or an approval of, any violation of any of the provisions of this code or of any other ordinance of the jurisdiction. Permits presuming to give authority to violate or cancel the provisions of this code or other ordinances of the jurisdiction shall not be valid. The issuance of a permit based on construction documents and other data shall not prevent the code official from requiring the correction of errors in the construction documents and other data. The code official is also authorized to prevent occupancy or use of a structure where in violation of this code or of any other ordinances of this jurisdiction.

**(L) Information on the permit.** The code official shall issue all permits required by this code on an approved form furnished for that purpose. The permit shall contain a general description of the operation or occupancy and its location and any other information required by the code official. Issued permits shall bear the signature of the code official, except when issued through a City authorized online permitting system.

**(M) Suspension or revocation.** The code official is authorized to suspend or revoke a permit issued under the provisions of this code wherever the permit is issued in error, on the basis of incorrect, inaccurate or incomplete information; in violation of any ordinance, regulation or any of the provisions of this code; or if any one of the following conditions exists:

- (a) The permit is used for a location or establishment other than that for which it was issued.
- (b) The permit is used for a condition or activity other than that listed in the permit.
- (c) Conditions and limitations set forth in the permit have been violated.
- (d) There have been any false statements or misrepresentations as to the material fact in the application for permit or plans submitted or a condition of the permit.
- (e) The permit is used by a different person or firm than the name for which it was issued.
- (f) The permittee failed, refused or neglected to comply with orders or notices duly served in accordance with the provisions of this code within the time provided therein.

(g) The permit was issued in error or in violation of an ordinance, regulation or this code.

**(N) FEES.**

**1) Payment of fees.** A permit shall not be valid until the fees prescribed by law have been paid. Nor shall an amendment to a permit be released until the additional fee, if any, has been paid.

**2) Schedule of permit fees.** A fee for each permit shall be paid as required, in accordance with the schedule as established by the City.

**3) Work commencing before permit issuance.** Except where authorized for emergencies by Section 85.13(B) exception, any person who commences any work before obtaining the necessary permits shall be subject to an additional fee established by the code official, which shall be in addition to the required permit fees.

**4) Related fees.** The payment of the fee for the construction, alteration, removal or demolition for work done in connection with, or concurrently with, the work authorized by a permit shall not relieve the applicant or holder of the permit from the payment of other fees that are prescribed by law.

**5) Refunds.** The code official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code provided the request is made in writing and file by the original permittee not later than 180 days after the date of permit issuance. The code official may authorize refunding of not more than 80 percent of the plan review fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or canceled before any plan review is done provided the request is made in writing and filed by the original applicant not later than 180 days after the date of application.

**6) Use of Consultants.** Whenever review of an application requires retention by the city for professional consulting services for other than normal plan review, the applicant shall reimburse the city the cost of such professional consulting services. This fee may be in addition to the normal plan review and permit fees. The city may require the applicant to deposit an amount with the city to be sufficient to cover anticipated costs to retain professional consultant services and to ensure reimbursement for such costs.

**85.15 Construction Documents**

**(A) Submittal documents.** Construction documents, special inspection and structural observation programs, and other data shall be submitted as required by the City in two or more sets with each application for a permit.

The construction documents shall be prepared by a registered design professional where required by the State of Washington. Where special conditions exist, the code official is authorized to require additional construction documents to be prepared by a registered design professional.

*Exception: The code official is authorized to waive the submission of construction documents and other data not required to be prepared by a registered design professional if it is found that the nature of the work applied for is such that reviewing of construction documents is not necessary to determine compliance with this code.*

**(B) Electrical Engineer.** Electrical plans for the following installations shall be prepared by, or under the direction of, a consulting electrical engineer registered under Chapter 18.43 RCW, and Chapters 180-29, 246B-320, and 388-97 WAC. All electrical plans must bear the engineer's stamp and signature.

- (1) All educational facilities, hospitals and nursing homes;
- (2) All services or feeders rated 1,600 amperes or larger;
- (3) All installations identified in the National Electrical Code requiring engineering supervision;
- (4) As required by the building official for installations which by their nature are complex, hazardous or pose unique design problems.

**(C) Information on construction documents.** Construction documents shall be drawn to scale upon suitable material. Electronic media documents are permitted to be submitted where approved by the code official. Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that it will conform to the provisions of this code and relevant laws, ordinances, rules and regulations, as determined by the code official.

Construction documents shall identify the name and classification of the facility and clearly show the electrical installation or alteration in floor plan view, include all switchboard and panelboard schedules and when a service or feeder is to be installed or altered, must include a riser diagram, load calculation, fault current calculation, and interrupting rating of equipment.

**(D) Penetrations.** Construction documents shall indicate where penetrations will be made for electrical systems and shall indicate the materials and methods for maintaining required structural safety, fire-resistance rating and fireblocking.

**(E) Load calculations.** Where an addition or alteration is made to an existing electrical system, an electrical load calculation shall be prepared to determine if the existing electrical service has the capacity to serve the added load.

**(F) Site plan.** The construction documents submitted with the application for permit shall be accompanied by a site plan showing to scale the size and location of new construction and existing structures on the site, distances from lot lines, the established street grades and the proposed finished grades; and it shall be drawn in accordance with an accurate boundary line survey. In the case of demolition, the site plan shall show construction to be demolished and the location and size of existing structures and construction that are to remain on the site or plot. The code official is permitted to waive or modify the requirement for a site plan where the application for permit is for alteration or repair or where otherwise warranted.

**(G) Plan review required.** Electrical plan review is required for all new or altered electrical projects in the following occupancies and/or installations:

1) Educational, institutional, or health care facilities/buildings as follows:

- (a) Hospital
- (b) Nursing home unit or long-term care unit
- (c) Boarding home
- (d) Assisted living facility
- (e) Private alcoholism hospital
- (f) Alcoholism treatment facility
- (g) Private psychiatric hospital
- (h) Maternity home
- (i) Ambulatory surgery facility
- (j) Renal hemodialysis clinic
- (k) Residential treatment facility for psychiatrically impaired children and youth
- (l) Adult residential rehabilitation center
- (m) Educational facilities
- (n) Institutional facilities

Exception: Electrical Plan review is not required for the above educational, institutional, or health care facilities buildings where:

- 1. Lighting specific projects that result in an electrical load reduction on each feeder involved in the project;
- 2. Low voltage systems;
- 3. Modification to existing electrical installations where all of the following conditions are met:

- a. Service or distribution equipment involved is rated less than 100 amperes and does not exceed 250 volts;
  - b. Does not involve emergency systems other than listed unit equipment per NEC 700.12(F);
  - c. Does not involve branch circuits or feeders of an essential electrical system as defined in NEC 517.2; and
  - d. Service and feeder load calculations are increased by 5% or less.
4. Stand-alone utility fed services that do not exceed 250 volts and less than 100 amperes where the project's distribution system does not include:
- a. Emergency systems other than listed unit equipment per NEC 700.12(F);
  - b. Critical branch circuits or feeders as defined in NEC 517.2, or
  - c. A required fire pump system.

- 2) Alterations in non-residential occupancies 2,500 square feet and greater.
- 3) Installations in occupancies, except one and two family dwellings, where a service or feeder rated 100 amperes or greater is installed or altered or if more than 100 amperes is added to the service or feeder.
- 4) All work on electrical systems operating at/over 600 Volts
- 5) All commercial generator installations or alterations
- 6) All work in areas determined to be hazardous (classified) location by the NEC.
- 7) If 60% or more of luminaires change.
- 8) Installations of switches or circuit breakers rated four hundred amperes or over except for one and two family dwellings.
- 9) Wind driven generators.
- 10) Solar photovoltaic systems.
- 11) Any proposed installation which cannot be adequately described in the application form.

**(H) Examination of Documents.** The code official shall examine or cause to be examined the accompanying construction documents and shall ascertain by such examinations whether the construction indicated and described is in accordance with the requirements of this code and other pertinent laws or ordinances.

**(I) Approval of construction documents.** When the code official issues a permit, the construction documents shall be approved, in writing or by stamp, as "Reviewed By", "Approved", or other similar words. One set of construction documents so reviewed shall be retained by the code official. The other set shall be returned to the applicant, shall be kept at the site of

work and shall be open to inspection by the code official or the authorized representative.

(1) Previous approvals. This code shall not require changes in the construction documents, construction or installation of electrical systems or equipment for which a lawful permit has been heretofore issued or otherwise lawfully authorized, and the construction of which has been pursued in good faith within 180 days after the effective date of this code and has not been abandoned.

(2) Phased approval. The code official is authorized to issue a permit for the installation of part of an electrical system before the construction documents for the electrical system have been submitted, provided that adequate information and detailed statements have been filed complying with pertinent requirements of this code. The holder of such permit shall proceed at the holder's own risk with the building operation and without assurance that a permit for the entire system will be granted.

**(J) Design Professional in Responsible Charge.** When it is required that documents be prepared by a qualified registered design professional, the building official shall be authorized to require the owner to engage and designate on the building permit application a registered design professional who shall act as the registered design professional in responsible charge. If the circumstances require, the owner shall designate a substitute registered design professional in responsible charge who shall perform the duties required of the original registered design professional in responsible charge. The building official shall be notified in writing by the owner if the registered design professional in responsible charge is changed or is unable to continue to perform the duties. The registered design professional in responsible charge shall be responsible for reviewing and coordinating submittal documents prepared by others, including phased and deferred submittal items, for compatibility with the design of the building. Where structural observation is required by IBC Chapter 17, the inspection program shall name the individual or firms who are to perform structural observation and describe the stages of construction at which structural observation is to occur (see also duties specified in IBC Chapter 17).

**(K) Deferred submittals.** For the purposes of this section, deferred submittals are defined as those portions of the design that are not submitted at the time of the application and that are to be submitted to the building official within a specified period. Deferral of any submittal items shall have the prior approval of the building official. The registered design professional in responsible charge, or the applicant, if no design professional is required, shall list the deferred submittals on the construction documents for review by the building official. Where a design professional is required, documents for deferred submittal items shall be

submitted to the registered design professional in responsible charge who shall review them and forward them to the building official with a notation indicating that the deferred submittal documents have been reviewed and been found to be in general conformance to the design of the building. The deferred submittal items shall not be installed until the design and submittal documents have been approved by the building official. The building official is authorized to charge an additional plan review fee to evaluate the deferred submittal under.

**(L) Amended construction documents (aka "Revisions").** Work shall be installed in accordance with the approved construction documents, and any changes made during construction that are not in compliance with the approved construction documents shall be resubmitted for approval as an amended set of construction documents (aka: Revisions). The building official may authorize minor field changes subject to the approval of the field inspector.

**(M) Retention of construction documents.** One set of approved construction documents shall be retained by the City for a period of not less than 180 days from date of completion of the permitted work, or as required by state or local laws.

#### **85.17 APPROVAL**

**(A) Approved materials and equipment.** All materials, equipment and devices approved by the code official shall be constructed and installed in accordance with such approval.

**(B) Technical assistance.** To determine the acceptability of technologies, processes, products, facilities, materials and uses attending the design, operation or use of a building or premises subject to the inspection of the department, the code official is authorized to require the owner or the person in possession or control of the building or premises to provide, without charge to the jurisdiction, a technical opinion and report. The opinion and report shall be prepared by a qualified engineer, specialist, laboratory or organization acceptable to the code official and shall analyze the properties of the design, operation or use of the building or premises and the facilities and appurtenances situated thereon, to recommend necessary changes. The code official is authorized to require design submittals to be prepared by and bear the stamp of a registered design professional.

**(C) Modifications.** Wherever there are practical difficulties involved in carrying out the provisions of this code, the code official shall have the authority to grant modifications for individual cases, provided the code

official shall first find that special individual reason makes the strict letter of this code impractical and that the modification is in compliance with the intent and purpose of this code, and that such modification does not lessen health, life and fire-safety requirements. The details of action granting modifications shall be recorded and entered in the permit file.

**(D) Alternative materials, methods, equipment and appliances.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any method of construction not specifically prescribed by this code, provided that any such alternative has been approved. An alternative material or method of construction shall be approved where the code official finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this code in quality, strength, effectiveness, fire resistance, durability and safety.

**(E) Material, equipment and appliance reuse.** Materials, equipment, appliances and devices shall not be reused unless such elements have been reconditioned, tested and placed in good and proper working condition and approved.

**(F) Required testing.** Wherever there is insufficient evidence of compliance with the provisions of this code, or evidence that a material or method does not conform to the requirements of this code, or in order to substantiate claims for alternative materials or methods, the code official shall have the authority to require tests as evidence of compliance to be made at no expense to the jurisdiction.

**(G) Test methods.** Test methods shall be as specified in this code or by other recognized test standards. In the absence of recognized and accepted test methods, the code official shall approve the testing procedures.

**(H) Testing agency.** All tests shall be performed by an approved agency.

**(I) Test reports.** Reports of tests shall be retained by the code official for the period required for retention of public records.

**(J) Alternate engineered design.** The design, documentation, inspection, testing and approval of an alternative engineered design electrical system shall comply with this section.

**1) Design criteria.** An alternative engineered design shall conform to the intent of the provisions of this code and shall provide an equivalent level of quality, strength, effectiveness, fire resistance, durability and

safety. Materials, equipment or components shall be designed and installed in accordance with the manufacturer's installation instructions.

**2) Submittal.** The registered design professional shall indicate on the permit application that the electrical system is an alternative engineered design. The permit and permanent permit records shall indicate that an alternative engineered design was part of the approved installation.

**3) Technical data.** The registered design professional shall submit sufficient technical data to substantiate the proposed alternative engineered design and to prove that the performance meets the intent of this code.

**4) Construction documents.** The registered design professional shall submit to the code official two complete sets of signed and sealed construction documents for the alternative engineered design. The construction documents shall include floor plans and a diagram of the work.

**5) Design approval.** Where the code official determines that the alternative engineered design conforms to the intent of this code, the electrical system shall be approved. If the alternative engineered design is not approved, the code official shall notify the registered design professional in writing, stating the reasons therefore.

**6) Inspection and testing.** The alternative engineered design shall be tested and inspected in accordance with the requirements of this code.

#### **85.19 INSPECTIONS AND TESTING**

**(A) General.** The code official is authorized to conduct inspections that are deemed necessary to determine the extent of compliance with the provisions of this code and to approve reports of inspection by approved agencies or individuals. All reports of such inspections shall be prepared and submitted in writing for review and approval. Inspection reports shall be certified by a responsible officer of such approved agency or by the responsible individual. The code official is authorized to engage such expert opinion as deemed necessary to report upon unusual, detailed or complex technical issues subject to the approval of the governing body. Electrical wiring or equipment subject to this chapter must be sufficiently accessible, at the time of inspection, to allow the inspector to visually inspect the installation to verify conformance with the NEC and any other electrical requirements of this chapter. Cables or raceways, fished according to the NEC, do not require visual inspection.

**(B) Required Inspections.** The code official, upon notification, shall make the inspections set forth in this section:

**(1) Underground.** Underground inspection shall be made after trenches or ditches are excavated and bedded, piping and conductors are installed, and before backfill is put in place. Where excavated soil

contains rocks, broken concrete, frozen chunks and other rubble that would damage or break the raceway, cable or conductors, or where corrosive action will occur, protection shall be provided in the form of granular or selected material, approved running boards, sleeves or other means.

**(2) Rough-in.** Rough-in inspection shall be made after the roof, framing, fireblocking and bracing are in place and all wiring and other components to be concealed are complete, and prior to the installation of wall or ceiling membranes. All required equipment grounding conductors installed in concealed cable or flexible conduit systems must be completely installed and made up at the time of the rough-in cover inspection.

**(3) Other inspections.** In addition to the inspections specified above, the code official is authorized to make or require other inspections of any construction work to ascertain compliance with the provisions of this code and other laws, which are enforced by the department of electrical inspection.

**(4) Final Inspection.** The final inspection shall be made after all work required by the permit is completed.

**(C) Concealed work.** Work shall remain accessible and exposed for inspection purposes until approved. It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Wherever any installation subject to inspection prior to use is covered or concealed without having first been inspected, the code official shall have the authority to require that such work be exposed for inspection. Neither the code official nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material required to allow inspection.

**(D) Inspection record card.** Work requiring a permit shall not be commenced until the permit holder or an agent of the permit holder shall have posted or otherwise made available an inspection record card such as to allow the code official to make conveniently the required entries thereon regarding inspection of the work. This card shall be maintained by the permit holder until final approval has been granted by the code official.

**(E) Approval required.** Work shall not be performed beyond the point indicated in each successive inspection and test without first obtaining the approval of the code official. The code official, upon notification, shall make the requested inspections and tests and shall either indicate the portion of the construction that is satisfactory as completed, or shall notify the permit holder or an agent of the permit holder wherein the same fails to comply with this code. Any portions that do not comply shall be corrected and such

portion shall not be covered or concealed until authorized by the code official. Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of this code or of other ordinances of the jurisdiction. Inspections presuming to give authority to violate or cancel the provisions of this code or of other ordinances of the jurisdiction shall not be valid.

**(F) Preliminary inspection.** Before issuing a permit, the code official is authorized to examine or cause to be examined buildings, structures and sites for which an application has been filed. The code official shall be notified when the installation is ready for inspection and is authorized to conduct the inspection within a reasonable period of time.

**(G) Identification.** The code official shall carry proper identification issued by the governing authority where inspecting structures, premises or facilities in the performance of duties under this code and shall be identified by proper credentials issued by this governing authority.

**(H) Impersonation prohibited.** A person shall not impersonate the code official through the use of a uniform, identification card, badge or any other means.

**(I) Right of entry.** Where it is necessary to make an inspection to enforce the provisions of this code, or where the code official has reasonable cause to believe that there exists in a structure or upon any premises a condition that is contrary to or in violation of this code, which makes the structure or premises unsafe, dangerous or hazardous, the code official is authorized to enter the structure or premises at reasonable times to inspect or to perform the duties imposed by this code, provided that if such structure or premises be occupied, that credentials be presented to the occupant and entry requested. If such structure or premises is unoccupied, the code official is authorized to first make a reasonable effort to locate the owner or other person having charge or control of the structure or premises and request entry. If entry is refused, the code official shall have recourse to the remedies provided by law to secure entry.

**(J) Inspection agencies.** The code official is authorized to accept reports of approved inspection agencies, provided such agencies satisfy the requirements as to qualifications and reliability.

**(K) Inspection requests.** It shall be the duty of the person doing the work authorized by a permit or the owner to notify the code official that such work is ready for inspection. It shall be the duty of the person requesting any inspections required by this code to provide access to and means for inspection of such work.

**(L) Assistance from other agencies.** The assistance and cooperation of police, building, fire and health department officials and all other officials shall be available as required in the performance of duties.

**(M) Contractors' responsibilities.** It shall be the responsibility of every contractor who enters into contracts for the installation or repair of electrical systems for which a permit is required to comply with adopted state and local rules and regulations concerning licensing.

**(N) Traffic management systems.**

(1) The city will perform the electrical inspection and acceptance of traffic management systems within its jurisdiction. A traffic management system includes:

- (a) Traffic illumination systems;
- (b) Traffic signal systems;
- (c) Traffic monitoring systems;
- (d) The electrical service cabinet and all related components and equipment installed on the load side of the service cabinet supplying electrical power to the traffic management system; and
- (e) Signalization system(s) necessary for the operation of a light rail system. A traffic management system can provide signalization for controlling vehicular traffic, pedestrian traffic, or rolling stock.

(2) The city recognizes that traffic signal conductors, pole and bracket cables, signal displays, traffic signal controllers/cabinets, and associated components used in traffic management systems are acceptable for the purpose of meeting the requirements of chapter 19.28 RCW provided they conform with the following standards or are listed on the Washington state department of transportation (WSDOT) qualified products list.

- (a) WSDOT/APWA Standard Specifications and Plans;
- (b) WSDOT Design Manual;
- (c) International Municipal Signal Association (IMSA);
- (d) National Electrical Manufacturer's Association (NEMA);
- (e) Federal Standards 170/Controller Cabinets;
- (f) Manual for Uniform Road, Bridge, and Municipal Construction;
- (g) Institute of Transportation Engineers (ITE); or
- (h) Manual of Uniform Traffic Control Devices (MUTCD).

(3) *Associated induction* detection loop or similar circuits will be accepted by the department or city authorized to do electrical inspections without inspection.

(4) For the licensing requirements of chapter 19.28 RCW, jurisdictions will be considered owners of traffic management systems when doing electrical work for another jurisdiction(s) under a valid interlocal agreement, as permitted by chapter 39.34 RCW. Interlocal agreements

for traffic management systems must be filed with the department or city authorized to do electrical inspections prior to work being performed for this provision to apply.

(5) Jurisdictions, with an established electrical inspection authority, and WSDOT may perform electrical inspection on their rights of way for each other by interlocal agreement. They may not perform electrical inspection on other rights of way except as allowed in chapter 19.28 or 39.34 RCW.

(6) Underground installations.

(a) In other than open trenching, raceways will be considered "fished" according to the NEC and do not require visual inspection.

(b) The department or city authorized to do electrical inspections will conduct inspections in open trenching within its jurisdiction upon request.

(7) Identification of traffic management system components. Local government jurisdictions or WSDOT may act as the certifying authority for the safety evaluation of all components.

(a) An electrical service cabinet must contain only listed components. The electrical service cabinet enclosure is not required to be listed but will conform to the standards in subsection (h) of this section.

(b) The local government jurisdiction must identify, as acceptable, the controller cabinet or system component(s) with an identification plate. The identification plate must be located inside the cabinet and may be attached with adhesive.

(8) Conductors of different circuits in same cable, enclosure, or raceway. All traffic management system circuits will be permitted to occupy the same cable, enclosure, or raceway without regard to voltage characteristics, provided all conductors are insulated for the maximum voltage of any conductor in the cable, enclosure, or raceway.

**(0) Testing.** Electrical work shall be tested as required in this code. Tests shall be performed by the permit holder and observed by the code official.

(1) **Apparatus, material and labor for tests.** Apparatus, material and labor required for testing an electrical system or part thereof shall be furnished by the permit holder.

(2) **Reinspection and testing.** Where any work or installation does not pass an initial test or inspection, the necessary corrections shall be made so as to achieve compliance with this code. The work or installation shall then be resubmitted to the code official for inspection and testing.

### **85.21 Service utilities**

**(A) Connection of service utilities.** No person shall make connections from a utility, source of energy, fuel or power to any building or system that

is regulated by this code for which a permit is required, until approved by the code official.

**(B) Temporary connection.** The code official shall have the authority to authorize the temporary connection of the building or system to the utility source of energy, fuel or power.

**(C) Authority to disconnect service utilities.** The code official shall have the authority to authorize disconnection of utility services or energy sources to the building, structure or system regulated by this code in case of an emergency where it is necessary to eliminate an immediate hazard to life or property. The code official shall notify the serving utility and, wherever possible, the owner and occupant of the building, structure or service system of the decision to disconnect prior to taking such action. If not notified prior to disconnecting, the owner or occupant of the building, structure or service system shall be notified in writing as soon as practical thereafter.

**(D) Connection after order to disconnect.** A person shall not make utility service or energy source connections to systems regulated by this code, which have been disconnected or ordered to be disconnected by the code official, or the use of which has been ordered to be discontinued by the code official until the code official authorizes the reconnection and use of such systems.

### **85.23 Unsafe systems and equipment**

**(A) Unsafe electrical systems.** An electrical system that is unsafe, constitutes a fire or health hazard, or is otherwise dangerous to human life, as regulated by this code, is hereby declared as an unsafe electrical system. Use of an electrical system regulated by this code constituting a hazard to health, safety or welfare by reason of inadequate maintenance, dilapidation, fire hazard, disaster, damage or abandonment is hereby declared an unsafe use. Such unsafe equipment and appliances are hereby declared to be a public nuisance and shall be abated by repair, rehabilitation, demolition or removal.

**(B) Authority to condemn electrical systems.** Wherever the code official determines that any electrical system, or portion thereof, regulated by this code has become hazardous to life, health or property, the code official shall order in writing that such electrical systems either be removed or restored to a safe condition. A time limit for compliance with such order shall be specified in the written notice. A person shall not use or maintain a defective electrical system or equipment after receiving such notice.

Where such electrical system is to be disconnected, written notice as prescribed in this code shall be given. In cases of immediate danger to life

or property, such disconnection shall be made immediately without such notice.

**(C) Dangerous conditions.** Wherever the code official shall find in any structure or upon any premises dangerous or hazardous conditions or materials, the code official is authorized to order such dangerous conditions or materials to be removed or remedied in accordance with the provisions of this code.

**(D) Record.** The code official shall cause a report to be filed on an unsafe condition. The report shall state the occupancy of the structure and the nature of the unsafe condition.

**(E) Notice.** If an unsafe condition is found, the code official shall serve on the owner, agent or person in control of the structure, a written notice that describes the condition deemed unsafe and specifies the required repairs or improvements to be made to abate the unsafe condition, or that requires the unsafe condition to be removed within a stipulated time.

**(F) Method of service.** Such notice shall be deemed properly served if a copy thereof is: (a) delivered to the owner personally; or (b) sent by certified or registered mail addressed to the owner at the last known address with the return receipt requested. If the certified or registered letter is returned showing that the letter was not delivered, a copy thereof shall be posted in a conspicuous place in or about the structure affected by such notice. Service of such notice in the foregoing manner upon the owner's agent or upon the person responsible for the structure shall constitute service of notice upon the owner.

### **85.25 Violations**

**(A) Unlawful acts.** It shall be unlawful for any person, firm or corporation to erect, construct, alter, extend, repair, move, remove, demolish or occupy any system or equipment regulated by this code, or cause same to be done, in conflict with or in violation of any of the provisions of this code.

#### **(B) Notice of Violation**

Where the code official finds any building, premises, vehicle, system or equipment that is in violation of this code, the code official is authorized to issue corrective orders.

(1) **Notice.** Wherever the code official determines violations of this code or observes an apparent or actual violation of a provision of this code or other codes or ordinances under the code official's jurisdiction, the code official is authorized to prepare a written notice of violation describing the conditions deemed unsafe and, where compliance is not immediate,

specifying a time for re-inspection. Such order shall direct the discontinuance of the illegal action or condition and the abatement of the violation.

(2) **Service.** Any order or notice issued pursuant to this code shall be served upon the owner, operator, occupant or other person responsible for the condition or violation, either by personal service, mail or by delivering the same to, and leaving it with, some person of responsibility upon the premises. For unattended or abandoned locations, a copy of such order or notice shall be posted on the premises in a conspicuous place at or near the entrance to such premises, and the order or notice shall be mailed by certified mail with return receipt requested or a certificate of mailing, to the last known address of the owner, occupant or both.

(3) **Compliance with orders and notices.** Orders and notices issued or served as provided by this code shall be complied with by the owner, operator, occupant or other person responsible for the condition or violation to which the order or notice pertains.

(4) **Failure to correct violations.** If the notice of violation is not complied with, the code official is authorized to request the legal counsel of the jurisdiction to institute the appropriate legal proceedings to restrain, correct or abate such violation or to require removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of any order or direction made pursuant thereto.

(5) **Failure to comply.** Failure to comply with an abatement notice or other corrective notice issued by the code official shall result in each day that such violation continues being regarded as a new and separate offense.

(6) **Unauthorized tampering.** Signs, tags or seals posted or affixed by the code official shall not be mutilated, destroyed or tampered with or removed without authorization from the code official.

**(C) Penalties.** Any person who fails to comply with the provisions of this code or who fails to carry out an order made pursuant of this code or violates any condition attached to a permit, approval or certificate shall be subject to the penalties as prescribed by law.

The imposition of the penalties herein described shall not prevent the legal officer of the jurisdiction from instituting appropriate action to prevent unlawful construction or to restrain, correct or abate a violation; or to prevent illegal occupancy of a structure or premises; or to stop an illegal act, conduct of business or occupancy of a structure on or about any premises.

**(D) Stop work order.** Upon notice from the code official that any electrical work is being done contrary to the provisions of this code or in a dangerous or unsafe manner, such work shall immediately cease. Such notice shall be in writing and shall be given to the owner of the property, or to the owner's agent, or to the person doing the work. The notice shall state the conditions under which work is authorized to resume.

(1) Where an emergency exists, the code official shall not be required to give a written notice prior to stopping the work.

(2) Any person who shall continue any work in or about the structure after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

### **85.27 Means of Appeal.**

A person shall have the right to appeal a decision of the code official. An application for appeal shall be based on a claim that the true intent of this code or the rules legally adopted hereunder, have been incorrectly interpreted, the provisions of this code do not fully apply, or an equally good or better form of construction is proposed.

Appeals shall be heard by the hearing examiner pursuant to the applicable Chapters of the City's Municipal Code.

### **85.29 Additional Electrical Provisions**

**(A)** All identified electrical hazards shall be abated. All identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the code official responsible for enforcement of this code. Electrical wiring, devices, appliances and other equipment which is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

**(B)** Electrical appliances and fixtures shall be tested and listed in published reports of inspected electrical equipment by an approved agency and installed in accordance with all instructions included as part of such listing.

**(C)** The cutting, notching and boring of wood and steel framing members, structural members and engineered wood products shall be in accordance with the International Building Code.

**(D)** Penetrations of walls, floors, ceilings and assemblies required to have a fire-resistance rating, shall be protected in accordance with the International Building Code. Where cables, conductors and raceways penetrate fireblocking or draftstopping, such penetrations shall be protected by filling the annular space with an approved fireblocking material.

**(E)** Where appliances requiring access are installed in attics or underfloor spaces, a luminaire controlled by a switch located at the required passageway opening to such space and a receptacle outlet shall be provided at or near the appliance location.

**(F)** Fuel gas piping shall not be used as a grounding electrode.

**(G)** Emergency and standby power systems required by the International Building Code or International Fire Code shall be installed in accordance with the International Building Code, the International Fire Code, NFPA 110, NFPA 111 and this code.

**(H)** Smoke control systems required by the International Building Code or International Fire Code shall be supplied with two sources of power. Primary power shall be the normal building power systems. Secondary power shall be from an approved standby source complying with this code. The standby power source and its transfer switches shall be in a separate room from the normal power transformers and switch gear, and shall be enclosed in a room constructed of not less than 1-hour fire-resistance-rated fire barriers, ventilated directly to and from the exterior. Power distribution from the two sources shall be by independent routes. Transfer to full standby power shall be automatic and within 60 seconds of failure of the primary power.

**(I)** Elements of the smoke management system relying on volatile memories or the like shall be supplied with uninterruptable power sources of sufficient duration to span 15-minute primary power interruption. Elements of the smoke management system susceptible to power surges shall be suitably protected by conditioners, suppressors or other approved means.

**(J)** In addition to meeting the requirements of this code, all signal and control wiring for smoke control systems, regardless of voltage, shall be fully enclosed within continuous raceways.

**(K)** Combustible electrical or electronic wiring methods and materials, optical fiber cable, and optical fiber raceway exposed within plenums regulated by Section 602 of the International Mechanical Code shall have a peak optical density not greater than 0.50, an average optical density not greater than 0.15, and a flame spread not greater than 5 feet (1524 mm) when tested in accordance with NFPA 262. Only type OFNP (plenum-rated non-conductive optical fiber cable) shall be installed in plenum-rated optical fiber raceways. Wiring, cable and raceways addressed in this section shall

be listed and labeled as plenum rated and shall be installed in accordance with this code.

**(L)** Combustible electrical equipment exposed within plenums regulated by Section 602 of the International Mechanical Code shall have a peak rate of heat release not greater than 100 kilowatts (kW), a peak optical density not greater than 0.50, and an average optical density not greater than 0.15 when tested in accordance with UL 2043. Combustible electrical equipment shall be listed and labeled.

**(M)** Permanently installed equipment and appliances powered by internal combustion engines and turbines shall be installed in accordance with the manufacturer's installation instructions, the International Mechanical Code, International Fuel Gas Code and NFPA 37.

**(N)** Stationary fuel cell power systems having a power output not exceeding 10MW shall be tested in accordance with ANSI CSA America FC1 and shall be installed in accordance with the manufacturer's installation instructions and NFPA 853.

**(O)** The power supply to the electrical control system for boilers shall be from a two-wire branch circuit that has a grounded conductor or from an isolation transformer with a two-wire secondary. Where an isolation transformer is provided, one conductor of the secondary winding shall be grounded. Control voltage shall not exceed 150 volts nominal, line to line. Control and limit devices shall interrupt the ungrounded side of the circuit. A means of manually disconnecting the control circuit shall be provided, and controls shall be arranged so that when de-energized, the burner shall be inoperative. Such disconnecting means shall be capable of being locked in the off position and shall be provided with ready access.

**(P)** Doors into electrical control panel rooms shall be marked with a plainly visible and legible sign stating ELECTRICAL ROOM or similar approved wording. The disconnecting means for each service, feeder or branch circuit originating on a switchboard or panelboard shall be legibly and durably marked to indicate its purpose unless such purpose is clearly evident.

**(Q)** In new construction, required smoke alarms shall receive their primary power from the building wiring where such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for overcurrent protection.

*Exception: Smoke alarms are not required to be equipped with battery backup in Group R-1 where they are connected to an emergency electrical system.*

**(R)** Where more than one smoke alarm is required to be installed within an individual dwelling unit or sleeping unit in Group R-2, R-3 or R-4, or within an individual sleeping unit in Group R-1, the smoke alarms shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms in the individual unit. The alarm shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed.

**(S)** Existing buildings. This section shall apply to existing buildings and structures that are within the scope of an adopted property maintenance code, abatement of dangerous buildings code, existing building code and/or housing code. Every occupied building shall be provided with an electrical system in compliance with the following requirements:

**(1) Service.** The size and usage of appliances and equipment shall serve as a basis for determining the need for additional facilities in accordance with this code. Dwelling units shall be served by a three-wire, 120/240 volt, single-phase electrical service having a rating of not less than 60 amperes.

**(2) Electrical system hazards.** Where it is found that the electrical system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.

**(3) Installation.** All electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and approved manner.

**(4) Receptacles.** Every habitable space in a dwelling shall be provided with at least two separate and remote receptacle outlets. Every laundry area shall be provided with at least one grounding-type receptacle outlet or a receptacle outlet with ground fault circuit interrupter protection. Every bathroom shall contain at least one receptacle outlet. Any new bathroom receptacle outlet shall have ground fault circuit interrupter protection.

**(5) Luminaires.** Every public hall, interior stairway, toilet room, kitchen, bathroom, laundry room, boiler room and furnace room shall be provided with at least one electric luminaire.

## Part 3 – NEC Amendments

### **90.7 Examination of equipment for safety**

Article 90.7 of the National Electrical Code is amended to read as follows:

**90.7 Examination of equipment for safety.** For specific items of equipment and materials referred to in this Code, examinations for safety made under standard conditions, to a recognized United States or harmonized international standard, provide a basis for approval where the record is made generally available through promulgation by organizations properly equipped and qualified for experimental testing, inspections of the run of goods at factories, and service-value determination through field inspections. This avoids the necessity for repetition of examinations by different examiners, frequently with inadequate facilities for such work, and the confusion that would result from conflicting reports on the suitability of devices and materials examined for a given purpose.

It is the intent of this Code that factory-installed internal wiring or the construction of equipment need not be inspected at the time of installation of the equipment, except to detect alterations or damage, if the equipment has been listed by a qualified electrical testing laboratory that is recognized as having the facilities described in the preceding paragraph and that requires suitability for installation in accordance with this Code.

### **100 National Electrical Code Article 100 amended — Definitions.**

Article 100 of the National Electrical Code is amended and supplemented by the addition of the following definitions to read as follows:

**“Accessible (as applied to wiring methods)”** means capable of being removed or exposed without damaging the building structure or finish or not permanently closed in by the structure or finish of the building including insulation.

**“Accessible, Readily (Readily Accessible)”** means capable of being reached quickly for operation, renewal, or inspections without requiring those to whom ready access is requisite to climb over or remove obstacles or

to resort to portable ladders, and so forth. In addition, it means that except for keys, no tools or other devices are necessary to gain access (e.g. covers secured with screws, etc.)

**"Adult residential rehabilitation center"** means a residence, place, or facility designed or organized primarily to provide twenty-four-hour residential care, crisis and short-term care or long-term individualized active treatment and rehabilitation for clients diagnosed or evaluated as psychiatrically impaired or chronically mentally ill as defined herein or in chapter 71.24 RCW.

**"Alcoholism treatment facility"** means a private place or establishment, other than a licensed hospital, operated primarily for the treatment of alcoholism.

**"Ambulatory surgical facility"** means a facility, not a part of a hospital, providing surgical treatment to patients not requiring inpatient care in a hospital. This term does not include a facility in the offices of private physicians or dentists, whether for individual or group practice, if the privilege of using such facility is not extended to physicians or dentists outside the individual or group practice.

**"Amusement structure"** means electrical or mechanical devices or combinations of devices operated for revenue and to provide amusement or entertainment to viewers or audiences at carnivals, fairs, or amusement parks. "Amusement structure" also means a bungee jumping device regardless of where located. "Amusement structure" does not include games in which a member of the public must perform an act, nor concessions at which customers may make purchases.

**"Amusement ride"** means any vehicle, boat, bungee jumping device, or other mechanical device moving upon or within a structure, along cables or rails, through the air by centrifugal force or otherwise, or across water, that is used to convey one or more individuals for amusement, entertainment, diversion, or recreation. "Amusement ride" includes, but is not limited to, devices commonly known as skyrides, ferris wheels, carousels, parachute towers, tunnels of love, bungee jumping devices, and roller coasters. "Amusement ride" does not include: (a) Conveyances for persons in recreational winter sports activities such as ski lifts, ski tows, j-bars, t-bars, and similar devices subject to regulation under chapter 70.88 RCW; (b) any single-passenger coin-operated ride that is manually, mechanically, or electrically operated and customarily placed in a public location and that does not normally require the supervision or services of an operator; (c) non-mechanized playground equipment, including but not limited to,

swings, seesaws, stationary spring-mounted animal features, rider-propelled merry-go-rounds, climbers, slides, trampolines, and physical fitness devices; or (d) water slides.

**"Approved Agency"** means an established and recognized agency regularly engaged in conducting tests or furnishing inspection services, where the agency has been approved by the code official.

**"Basement"** means that portion of a building that is partly or completely below grade plane. A basement shall be considered as a story above grade plane and not a basement where the finished surface of the floor above the basement is:

- (1) More than 1829 mm (six feet) above grade plane.
- (2) More than 1829 mm (six feet) above the finished ground level for more than 50% of the total building perimeter; or
- (3) More than 3658 mm (twelve feet) above the finished ground level at any point.

**"Boarding home"** means any home or other institution, however named, which is advertised, announced, or maintained for the express or implied purpose of providing board and domiciliary care to seven or more aged persons not related by blood or marriage to the operator. It must not include any home, institution, or section thereof which is otherwise licensed and regulated under the provisions of state law providing specifically for the licensing and regulation of such home, institution, or section thereof.

**"Building"** is a structure that stands alone or that is separated from adjoining structures by a minimum two hour rated fire walls, and protected openings complying with the provisions of Section 705 of the International Building Code. The extent and location of such fire walls shall provide a complete separation.

**"Certified electrical product"** means an electrical product to which a laboratory, accredited by the State of Washington, has the laboratory's certification mark attached.

**"Certification mark"** is a specified laboratory label, symbol, or other identifying mark that indicates the manufacturer produced the product in compliance with appropriate standards or that the product has been tested for specific end uses.

**"City"** means the City that adopts and enforces this code.

**"Code official"** means the person(s) or other designated authority charged with the administration and enforcement of this code, or a duly authorized representative.

**"Educational facility"** refers to a building or portion of a building used primarily for educational purposes by six or more persons at one time for twelve hours per week or four hours in any one day. Educational facility includes: Schools (preschool through grade twelve), colleges, academies, universities, and trade schools.

**"Electrical equipment"** includes electrical conductors, conduit, raceway, apparatus, materials, components, and other electrical equipment not exempted by RCW 19.28.006(9). Any conduit/raceway of a type listed for electrical use is considered to be electrical equipment even if no wiring is installed in the conduit/raceway at the time of the conduit/raceway installation.

**"Electrical products certification laboratory"** is a laboratory or firm accredited by the state of Washington to perform certification of electrical products.

**"Electrical products evaluation laboratory"** is a laboratory or firm accredited by the state of Washington to perform on-site field evaluation of electrical products for safety.

**"Family child day care home"** means the same as "family child care home" and "a child day care facility" licensed by the state, located in the family abode of the person or persons under whose direct care and supervision the child is placed, for the care of twelve or fewer children, including children who reside at the home. Electrical plan review is not required.

**"Field evaluated"** means an electrical product to which a field evaluation mark is attached. Field evaluation shall include job site inspection unless waived by the department, and may include component sampling and/or laboratory testing.

**"Field evaluation mark"** is a specified laboratory label, symbol, or other identifying mark indicating the manufacturer produced the product in essential compliance with appropriate standards or that the product has been evaluated for specific end uses.

**"Fished wiring"** is when cable or conduit is installed within the finished surfaces of an existing building or building structure (e.g., wall, floor or ceiling cavity).

**"High-Rise Building"** is a building having occupied floors located more than 75 feet above the lowest level of fire department vehicle access.

Exception: The following buildings and structures as defined in the International Building Code shall not be considered as a high-rise building:

- (1) Airport traffic control towers in accordance with IBC Section 412.
- (2) Open parking garages in accordance with IBC Section 406.3.
- (3) Buildings with an occupancy in Group A-5 in accordance with IBC Section 303.1
- (4) Low-Hazard special industrial occupancies in accordance with IBC Section 503.1.2.
- (5) Buildings with an occupancy in Group H-1, H-2 or H-3 in accordance with IBC Section 415.

**"Hospital"** means any institution, place, building, or agency providing accommodations, facilities, and services over a continuous period of twenty-four hours or more, for observation, diagnosis, or care of two or more individuals not related to the operator who are suffering from illness, injury, deformity, abnormality, or from any other condition for which obstetrical, medical, or surgical services would be appropriate for care or diagnosis.

**"IBC"** means the International Building Code.

**"Identification plate"** is a phenolic or metallic plate or other similar material engraved in block letters at least 1/4" (6 mm) high unless specifically required to be larger by this chapter, suitable for the environment and application. The letters and the background shall be in contrasting colors. Screws, rivets, or methods specifically described in this chapter shall be used to affix an identification plate to the equipment or enclosure.

**"Industrial control panel"** means a factory or user wired assembly of industrial control equipment such as motor controllers, switches, relays, power supplies, computers, cathode ray tubes, transducers, and auxiliary devices used in the manufacturing process to control industrial utilization equipment. The panel may include disconnecting means and motor branch circuit protective devices. Industrial control panels include only those used in a manufacturing process in a food processing or industrial plant.

**"Installation"** includes the act of installing, connecting, repairing, modifying, or otherwise performing work on an electrical system, component, equipment, or wire except as exempted by WAC 296-46B-925.

**"Institutional facility"** refers to a building or portion of a building used primarily for detention and correctional occupancies where some degree of restraint or security is required for a time period of twenty-four or more

hours. Such occupancies include, but are not restricted to: Penal institutions, reformatories, jails, detention centers, correctional centers, and residential-restrained care.

**"Labeled"** means an electrical product that bears a certification mark issued by a laboratory accredited by the state of Washington.

**"Laboratory"** may be either an electrical product(s) certification laboratory or an electrical product(s) evaluation laboratory.

**"Like-in-kind"** means having similar characteristics such as voltage requirement, current draw, circuit overcurrent and short circuit characteristics, and function within the system. Like-in-kind also includes any equipment component authorized by the manufacturer as a suitable component replacement part.

**"Listed"** means equipment has been listed and identified by a laboratory approved by the State of Washington for the appropriate equipment standard per this chapter.

**"Low voltage"** means:

- (1) NEC, Class 1 power limited circuits at 30 volts maximum.
- (2) NEC, Class 2 circuits powered by a Class 2 power supply as defined in NEC 725.121(A).
- (3) NEC, Class 3 circuits powered by a Class 3 power supply as defined in NEC 725.121(A).
- (4) Circuits of Telecommunications systems as defined in chapter 19.28 RCW.

**"Maternity home"** means any home, place, hospital, or institution in which facilities are maintained for the care of four or more women, not related by blood or marriage to the operator, during pregnancy or during or within ten days after delivery: provided, however, that this definition will not apply to any hospital approved by the American College of Surgeons, American Osteopathic Association or its successor.

**"Mezzanine"** is the intermediate level or levels between the floor and ceiling of any story with an aggregate floor area of not more than one-third of the area of the room or space in which the level or levels are located. Also see "basement" and "story."

**"NEC"** means National Electrical Code. Copies of the NEC are available from the National Fire Protection Association.

**"NRTL"** means Nationally Recognized Testing Laboratory accredited by the federal Occupational Safety and Health Administration (OSHA) after meeting the requirements of 29 CFR 1910.7.

**"Nursing home," "nursing home unit" or "long-term care unit"** means a group of beds for the accommodation of patients who, because of chronic illness or physical infirmities, require skilled nursing care and related medical services but are not acutely ill and not in need of the highly technical or specialized services ordinarily a part of hospital care.

**"Occupancy"** means the purpose for which a building, or part thereof, is utilized or occupied as defined by the International Building Code.

**"Point of contact"** for utility work, means the point at which a customer's electrical system connects to the serving utility system.

**"Private alcoholism hospital"** means an institution, facility, building, or equivalent designed, organized, maintained, or operated to provide diagnosis, treatment, and care of individuals demonstrating signs or symptoms of alcoholism, including the complications of associated substance use and other medical diseases that can be appropriately treated and cared for in the facility and providing accommodations, medical services, or other necessary services over a continuous period of twenty-four hours or more for two or more individuals unrelated to the operator, provided that this chapter will not apply to any facility, agency, or other entity which is owned and operated by a public or governmental body.

**"Private psychiatric hospital"** means a privately owned and operated establishment or institution which: provides accommodations and services over a continuous period of twenty-four hours or more, and is expressly and exclusively for observing, diagnosing, or caring for two or more individuals with signs or symptoms of mental illness who are not related to the licensee.

**"Renal hemodialysis clinic"** means a facility in a building or part of a building which is approved to furnish the full spectrum of diagnostic, therapeutic, or rehabilitative services required for the care of renal dialysis patients (including inpatient dialysis furnished directly or under arrangement). (NEC; Ambulatory Health Care Center)

**"Residential treatment facility for psychiatrically impaired children and youth"** means a residence, place, or facility designed or organized to provide twenty-four-hour residential care or long-term individualized, active

treatment for clients who have been diagnosed or evaluated as psychiatrically impaired.

**"Stand-alone amplified sound or public address system"** is a system that has distinct wiring and equipment for audio signal generation, recording, processing, amplification, and reproduction. This definition does not apply to telecommunications installations.

**"Story"** is that portion of a building included between the upper surface of a floor and the upper surface of the floor or roof next above. Next above means vertically and not necessarily directly above. Also see "basement" and "mezzanine."

**"Structure"** for the purposes of this chapter and in addition to the definition in the NEC, means something constructed either in the field or factory that is used or intended for supporting or sheltering any use or occupancy as defined by the IBC.

**"Telecommunications installations"** is as described in RCW 19.28.400 for both regulated carriers and unregulated local service providers.

**"Telecommunications local service provider"** is a regulated or unregulated (e.g., by the Federal Communications Commission or the utilities and transportation commission as a telephone or telecommunications provider) firm providing telecommunications service ahead of the telecommunications network demarcation point to an end-user's facilities.

**"Telecommunications network demarcation point"** as defined in RCW 19.28.400 means the point or interconnection between the service provider's communications cabling, terminal equipment, and protective apparatus and the customer's premises telecommunications cabling system. The location of this point for regulated carriers is determined by federal and state regulations and is applicable for both regulated carriers and unregulated local service providers.. The carrier should be contacted to determine the location policies in effect in the area,

**"Utility system"** means electrical equipment owned by or under the control of a serving utility that is used for the transmission or distribution of electricity from the source of supply to the point of contact and is further defined as installations under the exclusive control of electric utilities for the purpose of communication, transmission, and distribution of electric energy located in buildings used exclusively by utilities for such purposes or located outdoors on property owned or leased by the utilities or on public highways, streets, roads, etc., or outdoors by established rights on private property.

It is the intent that this chapter covers all premises' wiring or wiring other than utility owned metering equipment, on the load side of the service point of buildings, structures, or any other premises not owned or leased by the utility. Also, it is the intent that this chapter covers installations in buildings used by the utility for purposes other than listed in the previous paragraph, such as offices buildings, warehouses, garages, machine shops, and recreational buildings which are not an integral part of a generating plant, substation, or control center.

**"Utilization voltage"** means the voltage level employed by the utility's customer for connection to lighting fixtures, motors, heaters, or other electrically operated equipment other than power transformers.

**110.2 National Electrical Code Article 110.2 amended — Approval.**

Article 110.2 of the National Electrical Code is amended and supplemented by the addition of the following text to the end of Article 110.2:

All materials, devices, appliances, and equipment, not exempted in state law chapter 19.28. RCW, must conform to applicable standards recognized by the authority having jurisdiction, be listed, or field evaluated by an accredited electrical products testing laboratory. Equipment must not be energized until such standards are met, unless specific permission has been granted by the authority having jurisdiction.

**110.3 National Electrical Code Article 110.3 amended — Examination, Identification, Installation, and Use of Equipment.**

Article 110.3 of the National Electrical Code is amended and supplemented by the addition of a new subsection to be known as subsection 110.3(C), to read as follows:

**(C) Industrial control panels and utilization equipment.** Control panels and utilization equipment installed in industrial plants will be determined to meet the minimum electrical safety standards for installations by one of the following methods:

(1) Listing and Labeling by an accredited electrical products testing laboratory.

- (2) Field evaluation by an accredited electrical products testing laboratory;
- a) If the equipment usage is changed to other than industrial utilization equipment or electrical modifications are made to the equipment, the equipment must be successfully listed or field evaluated by an accredited electrical products testing laboratory.
  - b) The equipment must be permanently installed at the owner's facility and inspected per the requirements of this Chapter.

Use of industrial control panel(s) or equipment before its evaluation or final inspection, must be authorized by the Code Official or designated representative prior to its being energized.

**110.12 National Electrical Code Article 110.12 amended — Mechanical Execution of Work.**

Article 110.12 of the National Electrical Code is amended and supplemented by the addition of new subsections to be known as 110.12(C), 110.12(D) and 110.12(E), to read as follows:

**(C) Abandoned Conductors and Cables.** Electrical conductors or cables shall not be abandoned in place. Unused electrical conductors, or cables, regardless of voltage, and communication cables not in use shall be removed from the building or structure back to the originating panel board unless otherwise authorized by the authority having jurisdiction.

**(D) Old, Used or Damaged Material and Equipment.** Old, used or damaged electrical equipment, conductors or materials shall not be reinstalled or used in any new work without prior approval of the authority having jurisdiction.

**(E) Electrical Equipment submerged or exposed to water.** Electrical equipment and wiring that has been submerged or exposed to water must comply with the following:

- (1) All wire or cable listed for dry locations, molded-case breakers, fuses, electronic/solid state controllers, receptacles, lighting switches/dimmers, electric heaters, and any sealed device/equipment (e.g. relays, contactors, and similar equipment listed in NEMA 2006 publication titled "Evaluating Water Damaged Equipment") must be replaced.
- (2) All other electrical equipment (e.g. wiring, breaker panelboards, disconnect enclosed switches, switchgear, motor control centers, boiler controls, HVAC/R equipment, electric motors, transformers, appliances, water heaters, and similar equipment listed in NEMA 2006 publication titled "Evaluating Water Damaged Equipment") may after consultation

with and approval of the manufacturer, be reconditioned by properly trained personnel. The potential to recondition the equipment may vary with the nature of the electrical function, the degree of flooding, the age of the equipment, and the length of time the equipment was exposed to water.

(3) Before any electrical equipment is reconditioned and placed back into service, documentation shall be provided to the code official that the original manufacturer has reviewed and approved the reconditioning method, and that any recommended tests have been performed.

### **110.16 National Electrical Code Article 110.16 amended — Flash Protection.**

Article 110.16 of the National Electrical Code is amended and supplemented by the addition of the following text to the end of the first paragraph, to read as follows:

The flash protection marking shall be an identification plate or label meeting ANSI Standards Z535.4-1998 or be of a type approved by the Code Official or designated representative. The plate or label may be installed at the factory or in the field. The plate or label may be mounted using adhesive. The plate or label shall include all of the following:

- (1) The date of the flash hazard analysis.
- (2) The flash hazard category.
- (3) The incident energy level in cal/cm<sup>2</sup> at 18 inches from the flash hazard.
- (4) The flash hazard boundary.
- (5) The personal protective equipment that people within the Flash Hazard Boundary shall use.

The arc flash hazard shall be updated when a major modification, renovation or changes in the electrical distribution system that could affect the results of the arc flash hazard analysis takes place.

The arc flash hazard analysis shall take into consideration the design of the overcurrent protective device and its opening time, including its condition of maintenance.

*Exception: An arc flash analysis shall not be required where all of the following exists:*

- (1) The circuit supplying the electrical equipment is 240 volts or less.*
- (2) The electrical equipment is fed from only one transformer.*

*(3) The transformer feeding the electrical equipment is rated less than 125 kVA.*

**110.22 National Electrical Code Article 110.22 amended — Identification of Disconnecting Means.**

A. Article 110.22 of the National Electrical Code is amended and supplemented by the addition of the following text to subsection 110.22(A) to read as follows:

In other than dwelling units, an identification plate or label is required unless the disconnect is a circuit breaker or fused switch installed within a panelboard and its purpose is indicated by the panelboard schedule. The identification plate or label must include the identification designation of the circuit source panelboard that supplies the disconnect.

B. Article 110.22 of the National Electrical Code further is amended and supplemented by the addition of a new subsection to be known as subsection (D) to read as follows:

(D) The markings referenced in this section must be in the form of an identification plate or label in letters at least 13 mm (1/2") high.

**200.6 National Electrical Code Article 200.6 amended — Means of Identifying Grounded Conductors**

A. Article 200.6(A) of the National Electrical Code is amended and supplemented by the addition of the following exception, to read as follows:

*Exception: the grounded service conductor is permitted to be identified with a yellow jacket or with one or more yellow stripes.*

B. Article 200.6(B) of the National Electrical Code is amended and supplemented by the addition of the following exception, to read as follows:

*Exception: the grounded service conductor is permitted to be identified with a yellow jacket or with one or more yellow stripes.*

**210.8 National Electrical Code 210.8 amended — Ground Fault Circuit-Interrupter Protection for Personnel.**

A. Article 210.8 (A) of the National Electrical Code is amended and supplemented by the addition of the following text to read as follows:

*Exception: In a garage or unfinished basement, a red receptacle, with a red cover plate, supplying a fire alarm system is not required to have ground-fault circuit-interrupter protection. The receptacle must be identified for use only with the fire alarm system by an identification plate or cover with letters at least 1/4" high.*

B. Article 210.8(B)(2) of the National Electrical Code is amended and supplemented to read as follows:

- (2) Kitchens and food preparation areas
  - (a) For the purposes of NEC 210.8 (B), Kitchen means any area where utensils, dishes, etc. are cleaned or where food or beverages are prepared or cooked.

C. Article 210.8 (B) of the National Electrical Code is amended and supplemented by the addition of a new subsection 210.8 (B)(6) to read as follows:

- (6) All 125-volt, 15- and 20-ampere receptacles installed in wet locations must have ground-fault circuit interrupter protection for personnel.

**210.11 National Electrical Code 210.11 amended — Branch Circuits Required.**

Article 210.11 of the National Electrical Code is amended and supplemented by the addition of a new subsection to be known as subsection 210.11(C)(4), to read as follows:

**(4) Unfinished spaces.** In addition to the number of branch circuits required by other parts of this section, an additional raceway system or one dedicated 15 ampere minimum, 120 volt branch circuit shall be provided for unfinished spaces areas adaptable to future dwelling unit living areas that are not readily accessible to the service or branch circuit panelboard. One circuit or raceway is required for each 480 square feet or less of unfinished space area. If the total adjacent unfinished space area is less than 480 square feet the circuit can be an extension of an existing circuit. The circuits must terminate in a suitable box(es). The box must contain an identification of the intended purpose of the circuit(s). The branch circuit

panelboard must have adequate space and capacity for the intended load(s).

**210.12 National Electrical Code Article 210.12 amended - Arc-Fault Circuit-Interrupter Protection**

Section 210.12 (B) of the National Electrical Code is amended and supplemented by the addition of a new exception to read as follows:

*Exception #3: If an existing circuit is extended, arc-fault circuit interrupter protection is not required where approved by the code official.*

**215.10 National Electrical Code 215.10 amended — Ground-Fault Protection of Equipment.**

Article 215.10 of the National Electrical Code is amended and supplemented by the addition of a new paragraph following the first paragraph of Article 215.10 to read as follows:

Equipment ground fault protection systems shall be performance tested prior to being placed into service to verify proper installation and operation of the system as determined by the manufacturer's published instructions. This test or a subsequent test shall include all system feeders. A firm having qualified personnel and proper equipment must perform the tests required. A copy of the manufacturer's performance testing instructions and a written performance acceptance test record signed by the person performing the test must be provided for the inspector's records at the time of inspection. The performance acceptance test record shall include test details including, but not limited to all trip settings and measurements taken during the test. The equipment being tested shall be labeled identifying the date of the test, the firm performing the test, and all settings for the equipment tested.

**220.12 National Electrical Code 220.12 amended — Lighting Loads for Specified occupancies.**

Article 220.12 of National Electrical Code is amended and supplemented by the addition of an exception to read as follows:

*Exception: In determining feeder and service entrance conductor sizes and equipment ratings, the currently adopted Washington State Energy Code unit lighting power allowance table and footnotes may be used in lieu of NEC 220.12.*

**220.87 National Electrical Code 220.87 amended — Optional Calculations for Determining Existing Loads.**

Article 220.87 of National Electrical Code is amended and supplemented by the addition of the following text to the end of Subsection (1), Exception, to read as follows:

In addition to the 30-day demand data, the following information must be provided:

- (1) The date of the measurements.
- (2) A statement attesting to the validity of the demand data, signed by a registered professional engineer or the electrical administrator of the electrical contractor performing the measurements.
- (3) A diagram of the electrical system identifying the point(s) of the measurements.

**225.30 National Electrical Code Article 225.30 amended – Number of Supplies**

Article 225.30 (A) of the National Electrical Code is amended and supplemented by the addition of a new paragraph at the end of subsection (A) to read as follows:

If a property has only a single building that is supplied from a remote service, the building may be supplied by no more than two feeders originating from the service equipment. The service equipment must contain over current protection appropriate to each feeder. The building disconnecting means required by NEC 225.32 must be located within sight and within 5' of each other.

**225.32 National Electrical Code 225.32 amended — Location.**

A. Article 225.32 of the National Electrical Code is amended and supplemented by the addition of a new paragraph following the first paragraph of Article 225.32 to read as follows:

Feeder disconnects, panelboards, subpanels, and similar electrical equipment must be installed so that they are readily accessible and may not be installed in bathrooms, clothes closets, or shower rooms. All indoor feeder disconnects, panelboards and subpanels and similar electrical equipment must have adequate working space and be adequately illuminated.

B. Article 225.32 of the National Electrical Code is further amended and supplemented by the addition of new subsections to be known as Subsection 225.32(1) and 225.32(2), to read as follows:

**(1) Outside locations:** Where the feeder disconnecting means is installed outside of a building or structure it must be on the building or structure supplied. The building disconnecting means may supply only 1 building or structure unless the secondary building(s) or structure(s) has a separate building disconnecting means meeting the requirements of this subsection. The disconnecting means must have an identification plate with at least 1/2" high letters identifying:

- a. The building or structure served; and
- b. Its function as the building or structure main disconnect(s).

**(2) Inside location:** Where the feeder disconnecting means is installed inside the building or structure, it must be located so that the feeder raceway or cable extends no more than 15' inside the building or structure.

## **230.28 Service Mast as Support**


Article 230.28 of the National Electrical Code is amended and supplemented by the addition of new text and drawings to the end of the first paragraph to read as follows:

Where a raceway-type service mast is used as support for service-drop conductors, the following conditions must be met:



1. Raceway type service mast shall be a minimum of 2-inch rigid metal conduit.
2. An approved roof flashing shall be installed on each mast where it passes through a roof. Plastic, non-hardening mastic shall be placed between lead-type flashings and the conduit. Approved neoprene type roof flashings may be permitted.
3. Masts shall be braced, secured, and supported in such a manner that no pressure from the attached conductors will be exerted on a roof flashing, meter base, or other enclosures.

4. Utilization of couplings for a mast shall not be permitted above the point the mast is braced, secured, or supported. There must be a minimum of two means of support above any couplings used. A properly installed cable or stiff leg type support qualifies as one of the two required means of support.
5. Except as otherwise required by the serving utility, service mast support guys shall be installed if the service drop attaches to the mast more than 600 mm (24 in.) above the roof line or if the service drop is greater than 100' in length from the pole or support. Masts for support of other than service drops shall comply with this requirement as well.
6. Intermediate support masts shall be installed in an approved manner with methods identical or equal to those required for service masts.
7. For altered services, where it is impractical to install U bolt mast supports due to interior walls remaining closed, it may be permissible to use other alternate mast support methods such as heavy gauge, galvanized, electrical channel

### Surface Mount Meter Base



### Recessed Meter Base




Mast Not Over 26" High - Service Bracket 24" Or Less Above Roof Surface

### Service Mast Installation Details

### Drawing E-101

### Guying – Cable Type


### Guying – Stiff-Leg Type



Mast Over 26" High - Service Bracket Over 24" Above Roof Surface

## Service Mast Installation Details

## Drawing E-102



**Mast Not Over 26" High**  
 Service Bracket 24" Or Less Above Roof Surface

**Mast Over 26" High**  
 Service Bracket Over 24" Above Roof Surface

**Service Mast Installation Details** **Drawing E-103**

## **230.43 Wiring Methods for 600 Volts, Nominal, or Less**

Article 230.43 of the National Electrical Code is amended to read as follows:

**230.43 Wiring Methods for 600 Volts, Nominal, or Less.** Service-entrance conductors shall be installed in accordance with the applicable requirements of this code covering the type of wiring method used and shall be limited to the following methods:

- (1) Rigid metal conduit
- (2) Intermediate metal conduit
- (3) Wireways
- (4) Busways
- (5) Auxiliary gutters
- (6) Minimum schedule 40 Rigid polyvinyl chloride (PVC) conduit
- (7) Cablebus
- (8) Mineral-insulated, metal-sheathed cable (type MI).

*Exception: With the approval of the authority having jurisdiction existing electrical metallic tubing used for service entrance conductors may be permitted to remain, provided it meets all of the following conditions:*

- (1) It was installed prior to October 1984*
- (2) It is properly grounded*
- (3) The conduit is installed in a non-accessible location*
- (4) It is the proper size for the installed conductors*

## **230.70 VI. Service Equipment - Disconnecting Means – General**

A. Subsection 230.70(A)(1) of the National Electrical Code is amended and supplemented by the addition of new Subsections (a) and (b) to read as follows:

(a) Outside Location. The service disconnect means shall be installed on the building or structure it serves. The service disconnection means shall be labeled with a plate with 1/2 inch letters providing the following information:

- (1) The building or structure served; and
- (2) Its function as the building or structure main service disconnect(s).

(b) Inside Location. Where the service disconnect is installed inside the building or structure, it shall be located so that the service raceway extends no more than 15 feet inside the building or structure served. Service disconnecting means, panel boards, subpanels and similar electrical equipment shall be adequately illuminated.

B. Subsection 230.70(A)(2) of the National Electrical Code is amended to read as follows:

**(2) Bathrooms, clothes closets, toilet rooms and shower rooms.**

Service disconnection means, panel boards, subpanels and similar electrical equipment shall not be installed in bathrooms, clothes closets, toilet rooms or shower rooms.

**230.90 Service Equipment - Overcurrent Protection**

Exception No. 3 to Article 230.90(A) of the National Electrical Code is amended to read as follows:

*Exception No. 3: Two to six circuit breakers or sets of fuses shall be permitted as the overcurrent device to provide the overload protection. The sum of the ratings of the circuit breakers or fuses shall be permitted to exceed the ampacity of the service conductors, provided the calculated load does not exceed the ampacity of the service conductors. Where the service conductors have a lesser ampacity than the overcurrent protection or the equipment rating that they terminate in or on, an identification plate showing the ampacity of the conductors must be installed on the service equipment.*

**230.95 Ground-Fault Protection of Equipment**

Article 230.95 of the National Electrical Code is amended and supplemented by the addition of a new paragraph following the first paragraph to read as follows:

Equipment ground fault protection systems shall be performance tested prior to being placed into service to verify proper installation and operation of the system as determined by the manufacturer's published instructions. This test or a subsequent test shall include all system feeders. A firm having qualified personnel and proper equipment must perform the tests required. A copy of the manufacturer's performance testing instructions and a written performance acceptance test record signed by the person performing the test must be provided for the inspector's records at the time of inspection. The performance acceptance test record shall include test details including, but not limited to all trip settings and measurements taken during the test. The equipment being tested shall be labeled identifying the date of the test, the firm performing the test, and all settings for the equipment tested.

**230.202 VIII. Services Exceeding 600 Volts - Service-Entrance Conductors**

Subsection 230.202(B) of the National Electrical Code is amended and supplemented by the addition of new text to the end of the Subsection to read as follows:

Wiring methods for service conductors exceeding 600 volts, nominal, within a building or structure are limited to the following methods:

- (1) Rigid metal conduit
- (2) Intermediate metal conduit
- (3) Busways
- (4) Minimum schedule 80 Rigid polyvinyl chloride (PVC) conduit
- (5) Cablebus; metal-clad cable that is exposed for its entire length

**240.24 National Electrical Code Article 240.24 amended — Location on Premises – Not located over a step**

Article 240.24 (F) of the National Electrical Code is amended and supplemented by the addition of an exception to Article 240.24 (F) to read as follows:

*Exception – If the overcurrent device is a part of a panelboard that is being repaired or replaced in an existing location, the installation is allowed to be made above the stairs.*

**250.28 National Electrical Code Article 250.28 amended —Main Bonding Jumper and System Bonding Jumper – Separately Derived System with More than One Enclosure**

Article 250.28 (D)(3) of the National Electrical Code is amended to read as follows:

**(3) Separately Derived System with More than One Enclosure.**

Where a separately derived system supplies more than a single enclosure, the system bonding jumper for each enclosure shall be sized in accordance with 250.28 (D) (1) based on the largest ungrounded feeder/tap conductor serving that enclosure, or a single system bonding jumper shall be installed at the source and sized in accordance with 250.28 (D) (1) based on the equivalent size of the largest supply conductor determined by the largest sum of the areas of the corresponding conductors of each set.

## **250.50          Grounding electrode system**

Article 250.50 of the National Electrical Code is amended and supplemented by the addition of a new Subsection (1) to read as follows:

(1) At each new building or structure served, a concrete-encased grounding electrode complying with NEC 250.52(A)(3) shall be installed. All electrodes shall be inspected prior to covering, concealing or the placing of concrete.

*Exception: New buildings or structures, job site construction trailers, mobile/manufactured homes where not installed on a permanent concrete foundation.*

## **250.56          Resistance of rod, plate, and pipe electrodes**

Article 250.56 of the National Electrical Code is amended and supplemented by the addition of new text to the end of the first paragraph of Article 250.56 to read as follows:

If a ground resistance test is not performed to ensure a resistance to ground of twenty-five ohms or less, two or more electrodes as specified in NEC 250.52 must be installed a minimum of six feet apart.

*Exception: A temporary construction service is not required to have more than one rod or pipe electrode.*

## **250.68          National Electrical Code Article 250.68 amended — Grounding electrode conductor and bonding Jumper connection to Grounding Electrodes.**

Article 250.68 (A) of the National Electrical Code is amended to read as follows:

**(A) Accessibility.** All mechanical elements used to terminate a grounding electrode conductor or bonding jumper to grounding electrode or grounding electrode tap shall be accessible.

## **250-104(A)    Bonding of Piping Systems and Exposed Structural Steel**

Article 250.104(A) of the National Electrical Code is amended and supplemented by the addition of new Subsections (4) and (5) to read as follows:

**(4) Bonding hot and cold plumbing pipes.** The hot and cold plumbing pipes shall be bonded together. Hot and cold metallic plumbing lines are considered to be bonded together if, at the time of inspection, the inspector can determine that the lines are mechanically and electrically joined by one or more mixing valves.

**(5) Metallic stubs or valves.** Metallic stubs or valves used in nonmetallic plumbing systems are not required to be bonded to the electrical system unless required by the equipment manufacturer's instructions.

### **250.184(A) Solidly Grounded Neutral Systems**

Article 250.184(A) of the National Electrical Code is amended and supplemented by the addition of new Subsections (3) and (4) to read as follows:

#### **(3) Existing installations.**

(a) The use of a concentric shield will be allowed for use as a neutral conductor for extension, replacement, or repair, if all of the following are complied with:

- (1) The existing system uses the concentric shield as a neutral conductor;
- (2) Each individual conductor contains a separate concentric shield sized to no less than 33 1/2% of the ampacity of the phase conductor for 3-phase systems or 100% of the ampacity of the phase conductor for single-phase systems;
- (3) The new or replacement cable's concentric shield is enclosed inside an outer insulating jacket; and
- (4) Existing cable (i.e. existing cable installed directly in the circuit between the work and the circuit's overcurrent device) successfully passes the following tests:
  - (i) A cable maintenance high potential dielectric test. The test must be performed in accordance with the cable manufacturer's instruction or the 2001 NETA maintenance test specifications.
  - (ii) A resistance test of the cable shield. Resistance must be based on the type, size, and length of the conductor used as the cable shield using the conductor properties described in NEC Table 8 Conductor Properties.
  - (iii) A registered professional engineer must provide a specific certification to the authority having jurisdiction or designated representative in writing that the test results of the

maintenance high potential dielectric test and the resistance test have been reviewed by the electrical engineer and that the cable shield is appropriate for the installation. The registered engineer must stamp the certification document with the engineer's stamp and signature. The document may be in the form of a letter or electrical plans. Testing results are valid for a period of seven years from the date of testing. Cable will not be required to be tested at a shorter interval.

(a) A concentric shield used as a neutral conductor in a multi-grounded system fulfills the requirements of an equipment grounding conductor.

(b) Where a separate conductor is used as the neutral for an extension, replacement, or repair, the conductor must pass a resistance test. Resistance must be based on the type, size, and length of the conductor used as the cable shield using the conductor properties described in NEC Table 8 Conductor Properties.

**(4) New installations.**

(a) New installations shall not include extensions of existing circuits.

(b) The use of the concentric shield will not be allowed for use as a neutral conductor for new installations. A listed separate neutral conductor meeting the requirements of NEC 250.184(A) must be installed.

**300.11 National Electrical Code 300.11 amended — Securing and Supporting.**

Section 300.11(A) of the National Electrical Code is amended to read as follows:

(A) **Secured in Place.** Raceways, cable assemblies, boxes, cabinets, and fittings shall be securely fastened in place. Where not restricted by the authority having jurisdiction or Article 300, raceways, cables, or boxes may be installed in suspended ceilings provided the installation complies with the following:

- 1) The support wires are independent of the ceiling support system.
- 2) The support wires are a minimum #12 AWG and securely fastened to the structural ceiling and to the ceiling grid system.
- 3) Cables and raceways shall not be supported by ceiling grids.
- 4) Raceways and/or cables are not larger than three-quarter-inch trade size;
- 5) No more than two raceways or cables are supported by a support wire.

- a) The two-cable limitation does not apply to telecommunications cables, Class 2 cables, or Class 3 cables on support wires installed exclusively for such cables provided:
  - i) The support wire must be adequate to carry the cable(s) weight and all attached cables must be secured with approved fittings; and
  - ii) The maximum number of cables shall not be more than a 2 inch diameter when bundled together.
- 6) Raceways and cables are secured to the support wires by fittings designed and manufactured for the purpose.
- 7) The raceways or cables serve equipment that is located within the ceiling cavity or is mounted on or supported by the ceiling grid system.
  - a) Telecommunications cables, Class 2 cables, or Class 3 cables supported as required by this section, may pass through ceiling cavities without serving equipment mounted on or supported by the ceiling grid system.
- 8) NEC power limited, Class 2, and Class 3 cables must be secured in compliance with Article 334.30 and must be secured to boxes in compliance with Article 314.17.
- 9) Telecommunications cables must be secured in a manner that will not cause damage to the cables and at intervals not exceeding five feet. Cables are considered adequately supported when run through holes in building structural elements or other supporting elements. Telecommunications cables may be fished into inaccessible hollow spaces of finished buildings. Clamps or fittings are not required where telecommunications cables enter boxes.
- 10) Optical fiber cables must be secured in a manner that will not cause damage to the cables and at intervals not exceeding five feet. Cables are considered adequately supported when run through holes in building structural elements or other supporting elements. Optical fiber cables may be fished into inaccessible hollow spaces of finished buildings. Supports must allow a bending radius that will not cause damage to the cables.

**310.12 National Electrical Code Article 310.12 amended —  
Conductor Identification.**

Article 310.12 of the National Electrical Code is amended and supplemented by the addition of a new subsection to be known as subsection 310.12(D), to read as follows:

(D) Each cable operating at over 600 volts and installed on customer owned systems must be legibly marked in a permanent manner at each termination point and at each point the cable is accessible. The required

marking must use phase designation, operating voltage, and circuit number if applicable.

### **314.23 National Electrical Code 314.23 amended — Supports.**

Section 314.23(H) of the National Electrical Code is amended to read as follows:

(H) **Pendant Boxes.** An enclosure supported by a pendant shall comply with 314.23(H)(1) or (H)(2). In addition, a pendant box suspended by a flexible cord, must not contain conduit "knockouts" and the connection to the suspended box must utilize an integral threaded hub.

(1) **Flexible Cord.** box supported from a flexible cord must comply with the following.

(a) The maximum length of the cord for a suspended pendant drop from a permanently installed junction box to a suitable tension take-up device above the pendant box must not exceed six feet.

(b) The flexible cord must be supported at each end with an approved cord grip or strain relief connector fitting/device that will eliminate all stress on the conductors and the conductor connections.

(c) The flexible cord must be a minimum #14 AWG copper.

(d) The flexible cord ampacity must be determined using NEC Table 400.5(A) column A.

(e) The flexible cord must be hard or extra hard usage.

(2) **Conduit.** A box supporting lampholders or luminaires (lighting fixtures), or wiring enclosures within luminaires (fixtures) used in lieu of boxes in accordance with 300.15(B), shall be supported by rigid or intermediate metal conduit stems. For stems longer than 450 mm (18 in.), the stems shall be connected to the wiring system with flexible fittings suitable for the location. At the luminaire (fixture) end, the conduit(s) shall be threaded wrenchtight into the box or wiring enclosure, or into hubs identified for the purpose.

Where supported by only a single conduit, the threaded joints shall be prevented from loosening by the use of set-screws or other effective means, or the luminaire (fixture), at any point, shall be at least 2.5 m (8 ft) above grade or standing area and at least 900 mm (3 ft) measured horizontally to the 2.5 m (8 ft) elevation from windows, doors, porches, fire escapes, or similar locations. A luminaire (fixture) supported by a single conduit shall not exceed 300 mm (12 in.) in any horizontal direction from the point of conduit entry.

**334.15 National Electrical Code Article 334.15 amended – Exposed Work**

Article 334.15 (C) is amended and supplemented by the addition of the following exception to read as follows:

*Exception: The requirement for nonmetallic sheathed cable protection in this section does not apply in crawl spaces.*

**358.10 National Electrical Code Article 358.10 amended – Electrical Metallic Tubing: Type EMT – Wet Locations.**

Article 358.10 (C) of the National Electrical Code is amended and supplemented by the addition of a new paragraph following the first paragraph, to read as follows:

Where installed in wet locations, an equipment grounding conductor must be provided within the raceway and sized per NEC 250.122

**358.12 National Electrical Code Article 358.12 amended – Uses Not Permitted.**

Article 358.12 of the National Electrical Code is amended and supplemented by the addition of a new subsection to be known as subsection 358.12(7), to read as follows:

(7) Installed in direct contact with the earth or in concrete on or below grade.

**394.12 National Electrical Code Article 394.12 amended – Uses Not Permitted.**

Article 394.12 of the National Electrical Code is amended and supplemented by the addition of a new Exception to Article 394.12(5), to read as follows:

*Exception: Hollow spaces containing existing knob-and-tube wiring are allowed to be insulated provided that all of the following conditions are met:*

- 1. The wiring shall be surveyed by an appropriately licensed electrical contractor who must certify in writing to the authority having jurisdiction*

- that the wiring is in good condition with no evidence of improper overcurrent protection, conductor insulation failure or deterioration, and with no improper connections or splices. The electrical inspector must inspect all repairs, alterations, or extensions to the electrical system;*
- 2. The insulation shall meet Class I specifications as identified in the International Building Code, with a flame spread factor of 25 or less as tested using ASTM E84-81a. Foam insulation may not be used with knob-and-tube wiring;*
  - 3. All knob-and-tube circuits shall have overcurrent protection in compliance with NEC Table 310.16, 60 degree centigrade, Column C. Overcurrent protection shall be circuit breakers or Type S fuses.*

**406 National Electrical Code Article 406 amended — Tamper Resistant Receptacles.**

Article 406 of the National Electrical Code is amended and supplemented by the addition of a Section to be known as Section 406.15, to read as follows:

**406.15 Tamper-Resistant Receptacles in Other Locations.** Listed tamper-resistant receptacles or listed tamper-resistant receptacle cover plates are required in all licensed day care centers, all licensed children group care facilities and psychiatric patient care facilities where accessible to children five years of age and under. Listed tamper-resistant receptacles are required in psychiatric patient care facilities where accessible to psychiatric patients over five years of age.

**410.10 National Electrical Code Article 410.10 amended — Bathtub and Shower Areas.**

Section (D) of Article 410.10 of the National Electrical Code is amended to read as follows:

**(D) Bathtub and Shower Areas.** No parts of cord-connected luminaires (fixtures), chain-, cable-, or cord-suspended-luminaires (fixtures), lighting track, pendants, or ceiling-suspended (paddle) fans shall be located within a zone measured five feet horizontally and eight feet vertically from the top of the bathtub rim or shower stall threshold. This zone is all encompassing and includes the zone directly over the tub or shower stall. Luminaires (lighting fixtures) located in this zone shall be listed for damp locations, or listed for wet locations where subject to shower spray. These fixtures must be GFCI protected where there are exposed metal parts.

**410.62 National Electrical Code Article 410.62 amended —  
Cord-Connected Lampholders and Luminaires.**

Article 410.62 of the National Electrical Code is amended and supplemented by the addition of a new subsection to be known as subsection 410.62(C)(1)(3), to read as follows:

- (3) A ground-type attachment plug cap and receptacle connection at the source junction box is not required when the flexible cord complies with NEC 410.30 and the following:
- a. Connection to a source junction box must utilize an approved cable connector or clamp;
  - b. The flexible cord must be supported at each end with an approved cord grip or strain relief connector fitting/device that will eliminate all stress on the conductor connections;
  - c. The maximum length of the cord for a suspended pendant drop from a permanently installed junction box to a suitable tension take-up device above the pendant luminaire must not exceed six feet;
  - d. The flexible cord must be a minimum #14 AWG copper;
  - e. The flexible cord ampacity must be determined in NEC Table 400.5(A) column A;
  - f. The flexible cord must be hard or extra hard usage; and
  - g. A vertical flexible cord supplying electric discharge luminaires must be secured to the luminaire support as per NEC 334.30(A).

**422.10 National Electrical Code Article 422.10 amended —  
Branch-Circuit Rating.**

Article 422.10 of the National Electrical Code is amended and supplemented by the addition of a new paragraph at the end of Article 422.10(A), to read as follows:

Water heaters with a rated circuit load in excess of 3,500 watts, but less than 4900 watts, at 208 or 240 volts shall be provided with branch circuit conductors not smaller than #10 AWG copper or equal. Overcurrent protection shall comply with NEC 422.11(E).

**445.20 National Electrical Code Article 445.20 added —  
Generators**

Article 445 of the National Electrical Code is amended and supplemented by the addition of a new section to be known as section 445.20, to read as follows:

**445.20 Wind Driven Equipment.** Wind driven equipment includes alternators or generators that produce electrical current through the conversion of wind energy into electrical energy. Wind driven generation equipment must demonstrate conformance to applicable safety standards.

For utility interactive systems, any person making inter-connections between the generator system and the utility distribution network must consult the serving utility and are required to meet all additional utility standards.

All wind driven generator equipment and disconnecting means must be permanently identified as to their purpose, maximum voltages and type of current within the system with an identification plate.

**450.27 National Electrical Code Article 450.27 amended — Oil-Insulated Transformers Installed Outdoors.**

Article 450.27 of the National Electrical Code is amended and supplemented by the addition of the following text to the end of the last paragraph of Article 450.27 to read as follows:

Oil-Insulated transformers located adjacent to building(s) or structures shall comply with the following:

1. Transformers shall not be located closer than 2.5 m (8 ft) to any part of a building or structure constructed of combustible material including any eaves, overhangs or decks;
2. Transformers shall not be located closer than 900 mm (2 ft) to any part of a building or structure constructed of non-combustible material including any eaves, overhangs or decks and must be outside a line extended vertically from the ends of the eaves, overhangs or rooflines of the building or structure;
3. Transformers shall not be located closer than 2.5 m (8 ft) to any part of doors, windows, stairways, ventilation openings, other types of openings of all buildings or structures;
4. Transformers shall be located such that any oil leaking from the transformer will flow away from the building or structure and will not pool; and
5. Transformers located in areas subject to vehicular traffic shall be provided with adequate guarding.
6. Enclosures for total underground oil filled transformers shall not be located closer than 2.5 m (8 ft) to any part of a doorway, window, stairway or fire escape. Adequate space must be maintained above the enclosure so that a boom may be used to lift the transformer from the enclosure.

**450.42 National Electrical Code Article 450.42 amended – Walls, Roofs, and Floors.**

Article 450.42 Exception of the National Electrical Code is amended and supplemented to read as follows:

*Exception: Where transformers are protected with automatic sprinkler, water spray, carbon dioxide, or halon and installed 5 stories or less above finished grade, construction of 1-hour rating shall be permitted.*

**501.200 National Electrical Code Article 501 amended – Sewage Disposal Systems.**

Article 501 of the National Electrical Code is amended and supplemented by the addition of a new Section 501.200, to read as follows:

**501.200 Sewage Disposal Systems.**

(A) Pumping chambers for sewage, effluent, or grinder pumps in on-site and septic tank effluent pump (S.T.E.P.) disposal systems will be considered unclassified when not more than five residential units are connected to the system, residential units are connected to a utility sewage system, or when nonresidential systems have residential loading characteristics and all of the following general installations requirements are complied with:

- (1) The pumping chamber must be adequately vented. Venting may be accomplished through the building or structure plumbing vents where the system venting has been approved by the local jurisdiction authority or by a direct two-inch minimum vent to the atmosphere;
- (2) Equipment that in normal operation may cause an arc or spark must not be installed in any pumping chamber;
- (3) Float switches installed in a pumping chamber must be hermetically sealed to prevent the entrance of gases or vapors;
- (4) Junction boxes, conduits and fittings installed in the septic atmosphere must be of a noncorrosive type, installed to prevent the entrance of gases or vapors;
- (5) Where a conduit system is installed between the pumping chamber and the control panel, motor disconnect, or power source, an approved sealing method must be installed to prevent the migration of gases or vapors from the pumping chamber, and must remain accessible; and
- (6) Wire splices in junction boxes installed in pumping chambers must be suitable for wet locations.

(B) Residential wastewater loading characteristics in a nonresidential installation:

- (1) For systems that process less than three thousand five hundred gallons of wastewater per day may be certified by:

- (a) An on-site wastewater designer licensed under chapter 18.210 RCW; or
  - (b) A professional engineer, engaged in the business of on-site wastewater system design, licensed under chapter 18.43 RCW.
- (2) For systems that process three thousand five hundred gallons or more of wastewater per day may be certified by a professional engineer, engaged in the business of on-site wastewater system design, licensed under chapter 18.43 RCW. Written documentation must be signed and stamped by the designer or engineer and provided to the electrical inspector prior to inspection.
- (C) Any residential or nonresidential system that has building or structure floor drains being discharged into the system is classified as Class I Division 1. Drains from any commercially made tub, shower, basin, sink, or toilet are not considered floor drains.
- (D) Pumping chamber access covers can be covered by gravel, light aggregate, or noncohesive granulated soil, and must be accessible for excavation. Access covers that are buried must have their exact location identified at the electrical panel or other prominent location by an identification plate. The authority having jurisdiction for performing electrical inspections must approve the identification plate location.
- (E) Indoor grinder pumps installed in chambers with less than fifty gallons capacity are not required to meet the requirements of this section, except for the venting requirements in subsection (A)(1) of this section. Indoor grinder pumps installed in chambers with less than fifty gallons capacity are not classified systems as described in Article 500 NEC.
- (F) Secondary treatment effluent pumping chambers such as sand filters are unclassified, and require no special wiring methods.
- (G) Inspection approval is required prior to covering or concealing any portion of the septic electrical system, including the pump. New septic and effluent tanks containing electrical wires and equipment must be inspected and approved prior to being loaded with sewage.

**514.11 National Electrical Code Article 514.11 amended —  
Circuit Disconnects.**

Article 514.11 (A) of the National Electrical Code is amended and supplemented by the addition of the following subsections to be known as subsections 514.11 (A) (1), (2), and (3), to read as follows:

- (1) The disconnecting means shall disconnect all conductors of the circuit supplying all station dispensers and or pumps (including the grounded conductor) simultaneously from the source(s) of supply.

(2) For multi-circuit installations, an electrically held normally open contactor operated by a push-button or other suitable device may serve as the disconnecting means. The push button or disconnecting device shall not function as the resetting mechanism for the electrically held contactor. The resetting means shall meet the following:

- (a) Located at least 4.5 m (15 ft) or out of sight of the pushbutton; and
- (b) Protected by a suitable cover or guard; and
- (c) Identified with an approved identification plate that has white lettering on a black background.

(3) The disconnecting means shall be labeled with an identification plate, with letters at least 1" high, as the emergency disconnecting means.

The disconnecting means or operator must be:

- (a) Substantially red in color; and
- (b) For attended facilities – Must be readily accessible and must be located outdoors and within sight of the pump or dispensing equipment it controls; or
- (4) For unattended facilities – must be readily accessible and must be located within sight, but at least 20' from the pump or dispensing equipment it controls.

**517.29 National Electrical Code Article 517.29 amended —  
Essential Electrical Systems for Hospitals.**

Article 517 of the National Electrical Code is amended and supplemented by the addition of a new section to be known as section 517.29, to read as follows:

**517.29 General Requirements.** In health care facilities, the following methods must be used to determine adequate capacity and ratings of equipment providing electrical power for the essential electrical systems.

**(A) Systems in new facilities:**

(1) Emergency system: The emergency branch must consist of 2 branches known as:

- (a) Life safety system: The feeder conductors and equipment used to supply electrical power to the life safety branch must be determined by summation of the connected loads as determined by article 220 NEC and may not be subjected to any reduction due to the diversity of the loads. Feeder and equipment will be subject to a 125% multiplier for continuous loads in accordance with article 220 NEC.
- (b) Critical branch system: The feeder conductors and equipment must be calculated in accordance with article 220 NEC, including a level of diversity as determined by such article.

(2) Equipment branch: The feeder conductors and equipment used to supply electrical power to the equipment branch of the essential electrical system must be calculated in accordance with article 220 NEC, including a level of diversity as determined by such article.

(3) Generator sizing: The rating of the generator(s) supplying electrical power to the essential system of a health care facility must meet or exceed the summation of the loads determined in (a) and (b) of this subsection with no additional demand factors applied. Momentary X-ray loads may be ignored if the generator is rated at least 300% of the largest momentary X-ray load connected.

**(B)** Existing essential systems in facilities to which additional load is to be added:

(1) Existing loads: The existing loads of the separate branches of the essential electrical system may be determined by NEC Article 220.35(1).

(2) Added loads: Added loads to the separate branches of the essential electrical system must be determined by subsection (a) of this section.

(3) Generator sizing: The rating of the generator(s) supplying electrical power to the essential electrical system must meet or exceed the summation of the loads determined by (a) and (b) of this subsection with no additional demand factors applied.

## **519 National Electrical Code Article 519 created —Educational and Institutional Occupancies.**

The National Electrical Code is amended and supplemented by the addition of a new Article to be known as Article 519 – Educational and Institutional Occupancies to read as follows:

### **ARTICLE 519 Educational and Institutional Occupancies**

**519.1 Scope.** This article covers educational and institutional occupancies as defined in the Article.

**519.2 Wiring Methods.** The wiring methods in educational or institutional occupancies shall be limited to metallic or nonmetallic raceways, MI, MC, or AC cable. Places of Assembly within an Educational or Institutional occupancy may not be wired according to Section 518.4(b) or (c).

*Exception: Limited energy systems may use wiring methods in accordance with this Code.*

**525.1 National Electrical Code Article 525.1 amended — Scope.**

Article 525.1 of the National Electrical Code is amended to read as follows:

**525.1 Scope.** This article covers the installation of portable wiring and equipment for carnivals, circuses, fairs, and similar functions, including wiring in or on all structures. In addition to the requirements in this Article, all wiring and equipment for carnivals, circuses, fairs, and similar functions must also comply with WAC 296-403A.

**547.1 National Electrical Code Article 547 amended —  
Agricultural Buildings - Scope**

Article 547.1 of the National Electrical Code is amended to read as follows:

**547.1 Scope.** The provisions of this article shall apply to the following agricultural buildings or that part of a building or adjacent areas of similar or like nature greater than 1,000 square feet and used as part of a business or commercial farming activity as specified in 547.1 (A) and (B).

**553.4 National Electrical Code Article 553.4 amended —  
Location of Service Equipment.**

Article 553.4 of the National Electrical Code is amended to read as follows:

**553.4 Location of Service Equipment.** The service equipment for floating buildings and similar facilities shall have a readily accessible service rated disconnect located on the shoreline within sight of the shoreline connection of the dock, wharf or similar structure to which the floating building or similar facility is moored.

**553.6 National Electrical Code Article 553.6 amended —  
Feeder Conductors.**

Article 553.6 of the National Electrical Code is amended and supplemented by the addition of new paragraph following exception to read as follows:

Floating buildings or similar facilities shall have a disconnecting means located within sight of each floating building or similar facility. The disconnecting means shall be installed adjacent to but not in or on, the floating building or similar facility.

**553.7 National Electrical Code Article 553.7 amended —  
Installation of Services and Feeders.**

Article 553.7(B) of the National Electrical Code is amended and supplemented by the addition of new paragraph following the first paragraph, to read as follows:

Where flexible cables or cords are used they shall comply with Article 555.13(2). Conductors operating in excess of 600 volts, nominal, shall not be installed on floating portions of a floating building or similar facility.

**555.1 National Electrical Code Article 555.1 amended —  
Marinas and Boatyards - Scope.**

Article 555.1 of the National Electrical Code is amended and supplemented by amending the last paragraph of Article 555.1 to read as follows:

Private, non-commercial docking facilities constructed or occupied for the use of the owner or residence of the associated single family dwelling are covered by this article.

**555.5 National Electrical Code Article 555.5 amended —  
Transformers.**

Article 555.5 of the National Electrical Code is amended to read as follows:

**555.5 Transformers.** Transformers and enclosures shall be specifically approved for the intended location. The bottom of enclosures for transformers shall be located a minimum of 12" above the deck of a dock.

**555.7 National Electrical Code Article 555.7 amended —  
Location of Service Equipment.**

Article 555.7 of the National Electrical Code is amended to read as follows:

**Article 555.7 Location of Service Equipment.** The service equipment for floating docks or marinas shall be located adjacent to and within sight but not on or in, the floating structure.

**555.9 National Electrical Code Article 555.9 amended —  
Electrical Connections.**

Article 555.9 of the National Electrical Code is amended and supplemented by the addition of new exception to read as follows:

*Exception: Connections approved for wet locations.*

**555.10 National Electrical Code Article 555.10 amended —  
Electrical Equipment Enclosures.**

Article 555.10(B) of the National Electrical Code is amended and supplemented by the addition of new text after the first sentence, to read as follows:

All enclosures must be corrosion resistant. Gasketed enclosures must be arranged with a weep hole to discharge condensation.

**555.13 National Electrical Code Article 555.13 amended —  
Wiring Methods and Installation.**

Article 555.13(B)(1) of the National Electrical Code is amended and supplemented by amending the first paragraph to read as follows:

**(1) Overhead Wiring.** Overhead wiring shall be installed to avoid possible contact with masts and other parts of boats being moored, stored, serviced or moved.

**555.19 National Electrical Code Article 555.19 amended —  
Receptacles.**

Article 555.19(A)(4) of the National Electrical Code is amended to read as follows:

**(4) Ratings.** Shore Power Receptacles that provide shore power for boats must be rated not less than 20 amperes and must be single outlet type and must be of the locking and grounding type or pin and sleeve type.

**555.21 National Electrical Code Article 555.21 amended —  
Gasoline Dispensing Stations – Hazardous (Classified)  
Locations.**

Article 555.21(B)(1) of the National Electrical Code is amended and supplemented by deleting exception numbers 1 and 2 and adding new exception number 1 to read as follows:

*Exception No. 1: Dock, pier, or wharf sections that do not support fuel dispensers and may abut a section(s) that supports a fuel dispenser(s) are permitted to be unclassified where documented air space between the*

*sections is provided and where flammable liquids or vapors cannot travel to these sections. Documentation shall be provided as required in NEC 500.4(A).*

**590.1 National Electrical Code Article 590.1 amended — Scope.**

Article 590.1 of the National Electrical Code is amended and supplemented to read as follows:

**590.1 Scope.** The provisions of this article apply to temporary electrical power and lighting installations. For the purposes of this section, any circuit used for construction purposes is considered to be temporary.

**590.4 National Electrical Code Article 590.4 amended — General - Splices.**

Article 590.4 of the National Electrical Code is amended by revising subsection 590.4(G) to read as follows:

**(G) Splices.** On construction sites, a splice or junction box is not required for splices or junction connections where splices of conductors are at least ten feet above the grade or floor level and where not subject to contact from personnel.

**600.3 National Electrical Code Article 600.3 amended - Electrical Signs and Outline Lighting - Listing.**

Article 600.3 of the National Electrical Code is amended and supplemented by the addition of a new paragraph following the first paragraph, to read as follows:

Electric signs within the scope of Underwriters Laboratories Standards for Electric Signs UL 48 shall be listed. Electric signs not covered under the Standards for Electric Signs UL 48 shall be required to be installed in conformance with this Code or be field evaluated by an accredited electrical products testing laboratory.

**600.10 National Electrical Code Article 600.10 amended — Portable or Mobile Signs.**

Article 600.10 of the National Electrical Code is amended to read as follows:

**600.10 Portable and Mobile Signs**

(A) **Support.** Portable or mobile signs shall be adequately supported and readily movable without the use of tools.

(B) **Attachment Plug.** An attachment plug shall be provided for each portable or mobile sign.

(C) **Outdoor locations.** Portable or mobile signs in outdoor locations shall comply with 600.10(C)(1) and (C)(2).

(1) **Cords.** A weatherproof receptacle outlet that is weatherproof with the supply cord connected must be installed within six feet of each electrical sign. Extension cords are not permitted to supply portable outdoor signs.

(2) **Ground-Fault Circuit Interrupter.** Portable or mobile signs shall be provided with factory-installed ground-fault circuit-interrupter protection for personnel. The ground-fault circuit interrupter shall be an integral part of the attachment plug or shall be located in the power-supply cord within 300 mm (12 in.) of the attachment plug.

**600.21 National Electrical Code Article 600.21 amended —  
Ballasts, Transformers, and Electronic Power Supplies.**

Article 600.21 of the National Electrical Code is amended and supplemented by the addition of a new subsection (G), to read as follows:

(G) **Outside Awnings.** Luminaires installed in outdoor awnings shall be of a type that is suitable for wet locations and be connected by a wiring method suitable for wet locations. Fluorescent luminaires shall be installed so that no part of the luminaire is located closer than 6" to the awning fabric. Incandescent luminaires shall be installed so that no part of the luminaire is located closer than 18" to the awning fabric. Luminaires installed in outside awnings shall be controlled by a disconnect installed in conformance with Article 600.6.

**680.4 National Electrical Code Article 680.4 amended —  
Approval of Equipment.**

Article 680.4 of the National Electrical Code is amended and supplemented by the addition of the following new text to follow the first paragraph, to read as follows:

Electrical components which have failed and require replacement shall be replaced with identical products unless the replacement part is no longer available; in which case, a like-in-kind product may be substituted provided the mechanical and grounding integrity of the equipment is maintained.

**680.13 National Electrical Code Article 680.13 New — Field Installed Equipment.**

Article 680 of the National Electrical Code is amended and supplemented by the addition of new Section to be known as Article 680.13 to read as follows:

**680.13 Field Installed Equipment.** Field installed electrical equipment for a swimming pool, hot tub, spa or swim spa shall not be located closer than five feet from inside wall of the swimming pool, hot tub, spa or swim spa. The five feet separation may be reduced by the installation of a permanent barrier, such as a solid wall, fixed glass windows or doors, etc. The five feet separation shall be determined by the shortest path or route that a cord can travel from the spa, hot tub, swim spa, or swimming pool to the equipment.

Field installed electrical equipment must meet the following additional requirements:

1. Heaters are listed as a "swimming pool heater or a spa heater";
2. Pumps are listed as a "swimming pool pump" or "spa pump" or "swimming pool/spa pump";
3. Other equipment such as panelboards, conduit, and wire are suitable for the environment and comply with the applicable codes.
4. The field assembly or installation of "recognized components" shall not be permitted.

**680.25 National Electrical Code Article 680.25 amended — Feeders.**

Article 680.25 of the National Electrical Code is amended by revising subsection 680.25(A) to read as follows:

**(A) Wiring Methods.** A feeder between the service equipment and the remote panelboard is permitted to run in flexible metal conduit, an approved cable assembly that includes an equipment grounding conductor within its outer sheath (the equipment grounding conductor must comply with NEC 250.24(A)(5)), rigid metal conduit, intermediate metal conduit, liquidtight flexible nonmetallic conduit, rigid polyvinyl chloride conduit, reinforced thermosetting resin conduit, electrical metallic tubing (when installed on or within a building or crawl space), and electrical nonmetallic tubing (when installed within a building or crawl space). Aluminum conduit is not permitted.

**680.40 National Electrical Code Article 680.40 amended —  
General.**

Article 680.40 of the National Electrical Code is amended and supplemented by the addition of a new Subsection (A) and a new Subsection (B), to read as follows:

**(A) Modular, Self-Contained Spa or Hot Tubs.** Equipment assemblies for self-contained spas or hot tubs shall be installed within 1.5 m (5 ft.) from the inside wall of the spa or hot tub. Equipment assemblies shall be listed or field evaluated as a unit with the spa or hot tub.

**(B) Packaged Spa or Hot Tub Equipment Assemblies.** Equipment assemblies (skid pack) pre-packaged by a factory shall not be installed closer than 1.5 m (5 ft.) from the inside wall of the spa or hot tub and shall be listed as a package unit.

**680.70 National Electrical Code Article 680.70 amended —  
General.**

Article 680.70 of the National Electrical Code is amended and supplemented by the addition of the following text to the end of the first paragraph, to read as follows:

Hydromassage bathtubs must be listed as a unit and bear a listing mark which reads "Hydromassage bathtub."

**690.2 National Electrical Code Article 690.2 amended — Solar  
Photovoltaic Systems — Definitions**

Article 690.2 of the National Electrical Code is amended and supplemented by the addition of the following definitions, to read as follows:

**Photovoltaic system.** The photovoltaic system may conduct alternating current, direct current, or both and will comprise all interconnected circuits to the point of connection with the building distribution circuits or utility service conductors.

**Support structure, foundation, and tracker.** For the purpose of this section those portions of the array or tracker that are exclusively mechanical and are built specifically for the purpose of physically

supporting the modules or panels will not be considered part of the photovoltaic system as defined by this article.

**690.4 National Electrical Code Article 690.4 amended - Solar Photovoltaic Systems - Installation**

Article 690.4 of the National Electrical Code is amended and supplemented by the addition of two new subsections to be known as 690.4(E) and 690.4(F), to read as follows:

**(E) Utility interactive systems.** For utility interactive systems, persons making inter-connections between solar photovoltaic systems and the utility distribution network must consult the serving utility and are required to meet all additional utility standards.

**(F) Labels and Identification.** Required "WARNING" labels as specified by NEC 690 are required to be an identification plate on or immediately adjacent to the pertinent equipment.

All photovoltaic circuits must be identified at each overcurrent protection device(s) and panel directory(ies).

**690.7 National Electrical Code Article 690.7 amended – Solar Photovoltaic Systems - Maximum Voltage**

Article 690.7 of the National Electrical Code is amended and supplemented by replacing the second paragraph of Article 690.7(A) with the following text, to read as follows:

The open-circuit voltage temperature coefficients supplied in the instruction of listed photovoltaic modules will be used to determine the maximum direct current photovoltaic system voltage. Otherwise the voltage will be calculated using Table 690.7 of the National Electrical Code. For the purposes of this calculation, a temperature correction factor of 1.25 will be used unless another factor can be justified and is approved by the authority having jurisdiction.

**700.6 National Electrical Code Article 700.6 amended – Transfer Equipment.**

Article 700.6 of the National Electrical Code is amended and supplemented by the addition of a new subsection (E) to read as follows:

(E) Location. In high-rise buildings and underground buildings, per IBC 403 and 405 respectively, the emergency transfer switches where required by the IBC or this code shall be located in a separate room from the normal

power source including transformers and distribution equipment and shall be enclosed in a room constructed of not less than 2-hour fire-resistive-rated fire barriers ventilated directly to and from the exterior. The emergency transfer switches, where required by the IBC or this code in other buildings or uses, shall be located in a separate room from the normal power source including transformers and distribution equipment and shall be enclosed in a room constructed of not less than 1-hour fire-resistive-rated fire barriers ventilated directly to and from the exterior. Power distribution from the two sources to the emergency transfer switches shall be by independent routes.

*Exception: System components described in Article 701 may occupy the same dedicated spaces as emergency systems.*

#### **700.8 National Electrical Code Article 700.8 amended – Emergency Systems – Signs**

Article 700.8 of the National Electrical Code is amended and supplemented by the addition of the following paragraph prior to subsection (A) to read as follows:

Signs required in this section must be placed at the service disconnecting means and the meter base if the service disconnecting means and meter base are not located within sight and within 5 feet of each other.

#### **700.9 National Electrical Code Article 700.9 amended – Wiring, Emergency Systems.**

Article 700.9 of the National Electrical Code is amended and supplemented by amending Article 700.9(A) to read as follows:

##### **(A) Identification.**

(1) Emergency systems. All boxes and enclosures larger than 150 mm (6 in.) by 150 mm (6 in.) (including transfer switches, generators and power panels) for emergency circuits shall be permanently marked with an identification plate that is orange in color so they will be readily identified as a component of the emergency circuit or system. All other device and junction boxes for emergency systems and circuits shall be orange in color, both inside and outside.

(2) Smoke Control Systems. All boxes and enclosures larger than 150 mm (6 in.) by 150 mm (6 in.) (including transfer switches, generators

and power panels) for smoke control power and control circuits shall be permanently marked with an identification plate that is orange in color with a yellow diagonal stripe so they will be readily identified as a component of the smoke control circuit or system. All other device and junction boxes for smoke control systems and circuits shall be orange in color both inside and outside. Cover plates shall be orange in color with a yellow diagonal stripe.

(3) Stair and elevator pressurization systems. All boxes and enclosures larger than 150 mm (6 in.) by 150 mm (6 in.) (including transfer switches, generators and power panels) for stair and elevator pressurization system power and control circuits shall be permanently marked with an identification plate that is orange in color with a gray diagonal stripe so they will be readily identified as a component of the stair and elevator pressurization system. Raceways for stair and elevator pressurization system wiring shall be identified by labels or color coding which distinguish it from all other systems and shall be visible at the time of inspection. All other device and junction boxes for stair and elevator pressurization system power and control circuits shall be orange in color both inside and outside. Cover plates shall be orange in color with a gray diagonal stripe.

*Exception: In existing facilities, the existing nameplate identification color scheme may be retained where approved by the code official.*

## **700.12 National Electrical Code Article 700.12 amended – Sources of Power.**

A. Article 700.12 of the National Electrical Code is amended and supplemented by the addition of three new paragraphs following the last paragraph to read as follows:

In high-rise buildings and underground buildings, per IBC 403 and 405 respectively, the emergency source of power shall be located in a separate room from the normal power source including transformers and distribution equipment and shall be enclosed in a room constructed of not less than 2-hour fire-resistive-rated fire barriers ventilated directly to and from the exterior.

In other buildings or uses the emergency source of power, where required by the IBC or this code shall be located in a separate room from the normal power source including transformers and distribution equipment and shall be enclosed in a room constructed of not less than 1-hour fire-resistive-rated fire barriers ventilated directly to and from the exterior.

Power distribution from the emergency source to the emergency transfer switch shall be by an independent route from the normal source.

B. Article 700.12(B)(6) of the National Electrical Code is amended and supplemented by the addition of new text following the first paragraph to read as follows:

A generator set located less than 3 m (10 ft) from the building(s) shall be enclosed within an approved structure of 1-hour fire resistive construction. Where located more than 3 m (10 ft) but less than 6 m (20 ft) shall be within an approved enclosure.

**700.27 National Electrical Code Article 700.27 amended – Coordination.**

Article 700.27 of the National Electrical Code is amended and supplemented by the addition of a new exception #2 following the first exception to the first paragraph to read as follows:

*Exception #2: The requirements for selective coordination described are not required where the emergency system was installed prior to June 1, 2006. For new emergency systems that are supplied from an existing emergency system installed prior to June 1, 2006, the new portion of the emergency system shall comply with NEC 700.27. The ground fault sensing function of overcurrent protective devices will only be required to selectively coordinate with the ground fault sensing functions of other overcurrent protective devices.*

**700.30 National Electrical Code Article 700.30 new – Smoke Control Systems, Pressurization Wiring and Equipment.**

Article 700 of the National Electrical Code is amended and supplemented by the addition of a new section to be known as Section 700.30 to read as follows:

**700.30 Smoke Control Systems, Pressurization Wiring and Equipment.** Where smoke control, stair pressurization and elevator pressurization is required by the City Building Code, all power and control wiring and equipment, including the emergency source of power and transfer switch(s) for smoke control, stair pressurization and elevator pressurization systems shall be installed in accordance with this Article (NEC 700-Emergency Systems), and IBC Section 403 HIGH-RISE BUILDINGS, IBC Section 405 UNDERGROUND BUILDINGS and IBC Section 909 SMOKE CONTROL SYSTEMS as amended and adopted by the City Building Code.

**701.7 National Electrical Code Article 701.7 amended – Transfer Equipment.**

Article 701.7 of the National Electrical Code is amended and supplemented by the addition of a new subsection (D) to read as follows:

(D) Location. In high-rise buildings the legally required standby source of power and its transfer switches shall be located in a separate room from the normal power source including transformers and distribution equipment and shall be enclosed in a room constructed of not less than 2-hour fire-resistive-rated fire barriers ventilated directly to and from the exterior. Power distribution from the two sources shall be by independent routes.

*Exception: System components described in Article 700 may occupy the same dedicated spaces as the legally required standby systems.*

**701.9 National Electrical Code Article 701.9 amended – Legally Required Standby Systems – Signs**

Article 701.9 of the National Electrical Code is amended and supplemented by the addition of the following paragraph prior to subsection (A) to read as follows:

Signs required in this section must be placed at the service disconnecting means and the meter base if the service disconnecting means and meter base are not located within sight and within 5 feet of each other

**701.11 National Electrical Code Article 701.11 amended – Legally Required Standby Systems.**

Article 701.11(B)(5) of the National Electrical Code is amended and supplemented by the addition of new text following the first paragraph to read as follows:

A generator set located less than 3 m (10 ft) from the building(s) shall be enclosed within an approved structure of 1-hour fire resistive construction. Where located more than 3 m (10 ft) but less than 6 m (20 ft) shall be within an approved enclosure.

**701.18 National Electrical Code Article 701.18 amended – Coordination.**

Article 701.18 of the National Electrical Code is amended and supplemented by the addition of a new exception following the first paragraph to read as follows:

*Exception: The requirements for selective coordination described are not required where the legally required standby system was installed prior to June 1, 2006. For new legally required standby systems that are supplied from an existing legally required standby system installed prior to June 1, 2006, the new portion of the legally required standby system shall comply with NEC 701.18. The ground fault sensing function of overcurrent protective devices will only be required to selectively coordinate with the ground fault sensing functions of other overcurrent protective devices.*

**702.8 National Electrical Code Article 702.8 amended –  
Optional Standby Systems – Signs**

Article 702.8 of the National Electrical Code is amended and supplemented by the addition of the following paragraph prior to subsection (A) to read as follows:

Signs required in this section must be placed at the service disconnecting means and the meter base if the service disconnecting means and meter base are not located within sight and within 5 feet of each other

**725.3 National Electrical Code Article 725.3 amended – Other  
Articles.**

Article 725.3 of the National Electrical Code is amended and supplemented by the addition of Subsection (H) to read as follows:

**(H) Suspended Ceilings.** The installation of Class 1, Class 2 and Class 3 circuits must comply with Section 300.11(A).

**760.3 National Electrical Code Article 760.3 amended – Other  
articles.**

Article 760.3 of the National Electrical Code is amended and supplemented by the addition of a new subsection (H), to read as follows:

**(H) Suspended Ceilings.** The installation of fire alarm cables and raceways installed in hollow spaces of suspended ceilings shall comply with Section 300.11(A) of this code.

**760.12 National Electrical Code Article 760.12 amended – Fire Alarm Systems.**

Article 760 of the National Electrical Code is amended and supplemented by the addition of a new Section 760.12 to read as follows:

**760.12 Detection and control systems.** Wiring for fire detection systems providing power, detection, or control input or output signals to mechanical smoke control systems, stair and elevator pressurization systems or elements thereof shall be fully enclosed within a continuous metallic raceway system. The installation of the wiring system shall be installed in accordance with this Article (NEC 760-Fire Alarm Systems), IBC Section 403 HIGH-RISE BUILDINGS, IBC Section 405 UNDERGROUND BUILDINGS and IBC Section 909 SMOKE CONTROL SYSTEMS as amended and adopted by the City Building Code. The installation shall ensure the survivability of circuits for the specified time for evacuation of the building as determined by the Fire Code Official.

**760.30 National Electrical Code Article 760.10 amended – Fire alarm circuit identification.**

Article 760.30 of the National Electrical Code is amended and supplemented by the addition of new text to follow the end of the first paragraph, to read as follows:

Device and junction boxes for fire alarm systems shall be red in color, both inside and outside. Power-limited fire protective signaling circuit conductors shall be durably and plainly marked in or on junction boxes or other enclosures to indicate that it is a power-limited fire protective signaling circuit.

All device boxes, junction boxes and enclosures for smoke control systems larger than 150 mm (6 in.) by 150 mm (6 in.) shall be permanently marked with an identification plate that is red in color with a yellow diagonal stripe so they will be readily identified as a component of the smoke control circuit or system. All other device and junction boxes for smoke control systems and circuits shall be red in color both inside and outside. Cover plates shall be red in color with a yellow diagonal stripe.

**770.3 National Electrical Code Article 770.3 amended — Other Articles.**

Article 770.3 of the National Electrical Code is amended and supplemented by the addition of Subsection (C) to read as follows:

**(C) Suspended Ceilings.** The installation of optical fiber cables and raceways must comply with Section 300.11(A).

**800.3 National Electrical Code Article 800.3 amended — Other Articles.**

Article 800.3 of the National Electrical Code is amended and supplemented by the addition of Subsection (D) to read as follows:

**(D) Suspended Ceilings.** The installation of communications cables must comply with Section 300.11(A).

**800.30 National Electrical Code Article 800 amended — Communication Circuits.**

Article 800 of the National Electrical Code is amended and supplemented by the addition of a new Section 800.30 to read as follows:

**800.30 Designation of Telecommunications Network Demarcation Point.**

(A) At the point of telecommunications network demarcation, the telecommunications installer must install an identification plate with the following information:

- (1) "Point of demarcation";
- (2) Name of telecommunications utility; and
- (3) Name of customer/end user of the system.

(B) The telecommunications installer must confer with the telecommunications utility when determining the point of demarcation.