



City of Bellevue Fire Department
 P.O. Box 90012
 Bellevue, WA 98009 (425) 452-6872

Operational Permit Application Liquefied Petroleum Gases

Work or activity requiring a permit shall not commence until such work or activity has been inspected and authorized with a valid permit. Violation of this condition may result in additional permit or inspection fees.

GENERAL INFORMATION (to be completed by the permit applicant (PLEASE PRINT))

Business Name:		
Address:		
City:	State:	Zip:
Contact Person:	Phone No.	
Email Address:		

LOCATION OF PERMITTED ACTIVITY (if different than above (PLEASE PRINT))

Business Name:		
Address:		
City:	State:	Zip:

PERMIT BILLING (if different than above (PLEASE PRINT)) *(Permits will be billed by the City of Bellevue)*

Business Name:		
Address:		
City:	State:	Zip:
Contact Person:	Phone No.	
Email Address:		

[Click here](#) for the current permit fee. **Note:** This fee will change every January 1st based on the current Seattle Consumer Price Index. Governmental or non-profit organizations are exempt from permit fees. If non-profit, please provide IRS documentation for non-profit status.

- Temporary use permits are invoiced within 30 days of permit issuance.
- Until revoked permits are invoiced January each year.
- All permits are subject to a late fee if not paid within 30 days of receipt.

 Applicant Signature

 Date

FIRE PREVENTION OFFICE USE ONLY:

Specific Permit Conditions:	
Application Disposition: <input type="checkbox"/> Approved <input type="checkbox"/> Denied	
Reason for Denial:	
Reviewed / Inspected By:	Date:



Post Office Box 90012 • Bellevue, Washington • 98009 9012

PERMIT CONDITIONS

Liquefied Petroleum Gases

The following conditions shall be adhered to at all times for the permit to be valid.

1. LP gas shall not be used in basements, pit or similar locations.
2. Portable LP-Gas containers shall not be used in buildings. *EXCEPTIONS:*
 - A. In a factory used in the processing, research or experimentation not to exceed 735 pounds per manifold.
 - B. In a school used for research and experimentation not to exceed 50 pounds.
3. Only self-contained torch assemblies shall be having water capacity of 2 ½ pounds shall be used in a building.
4. LP-Gas containers shall only be used in buildings under construction.
5. Containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity.
6. LP-Gas containers shall be located with respect to building, property lines and public way. Distances shall be noted on the permit.
7. All equipment, containers, cylinders and tank shall be of an approved type.
8. LP-Gas shall not be released into the air unless through an approved device.
9. Smoking is prohibited around LP-Gas containers.
10. Clearance of 10 feet shall be provided between LP-Gas containers and other combustibles.
11. LP-Gas containers, cylinders and tanks shall be protected from vehicle impact.
12. LP-Gas containers shall not be stored within 10 feet of an exit or exit way.
13. LP-Gas containers shall not be stored on a roof.
14. Fire Protection is required for installations of LP-Gas over 4000 pounds.
15. Fire extinguishers shall be provided in the areas of LP-Gas use and storage. A minimum of a 40-BC shall be located within a minimum of 10 feet with a maximum of 30 feet from the LP-Gas container.
16. Empty containers that have been in service shall be considered as full containers for the purpose of determining the quantities of LP-Gas allowed.