



NOTES:

1. FOUNDATION DRAIN AND DOWNSPOUT DRAIN MUST BE KEPT SEPARATE TO 2-FT. MINIMUM FROM THE STRUCTURE. THE DRAINS MUST BE TIGHTLINED TO THE STORM CONNECTION.



City of
Bellevue

NO SCALE

TITLE

SINGLE FAMILY FOUNDATION DRAIN
AND DOWNSPOUT DRAIN

NO. EC-22

REV. DATE 10/2000