



- NOTES:**
1. TRENCH SHALL NOT BE LOCATED WITHIN 30' OF A WELL OR ANY PART OF A SEPTIC SYSTEM.
 2. TOP ELEVATION OF GRADE BOARD MUST BE BELOW RIM OF CATCH BASIN AND FOOTING DRAIN INVERT.
 3. IF MAX OVERFLOW ELEVATION CANNOT BE MET, THEN FOOTING DRAIN WILL REQUIRE A SEPARATE AND UPSLOPED FOOTING DRAIN.
 4. IF LENGTH REQUIREMENT CANNOT BE MET, MUST BE PUMPED TO APPROVED DISCHARGE.



City of Bellevue

STORM AND SURFACE WATER UTILITY

TITLE

ROOF DOWN SPOUT
DISPERSAL TRENCH DETAIL