



NOTES:

- 1 J-BOLT DIAMETER:
  - PIPE DIAMETER LESS THAN OR EQUAL TO 6": 7/8", 6" & 8" PIPE: 1", 10" = 1-1/4".
  - PIPE DIAMETER GREATER THAN 12": 1-1/2".
- 2 TIGHTEN TOP NUTS TO TENSION BOLTS.
- 3 TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.
- 4 COAT ALL EXPOSED PORTIONS OF BOLTS WITH COROTHANE 1 COAL TAR (URETHANE WITH MICACEOUS IRON OXIDE) PRIOR TO EMBEDMENT IN CONCRETE. AFTER ASSEMBLY, TOUCH UP ANY MISSING COATING ON BAR THREADS AND BOLTS. STAINLESS STEEL PARTS DON'T REQUIRE PAINTING.



City of  
Bellevue

WATER UTILITY

**TITLE**

PIPE CLAMP AND ANCHOR RODS  
FOR CONCRETE BLOCKING