



HOUSE OVER 2' ABOVE
MAXIMUM HYDRAULIC
GRADIENT OF THE
UPSTREAM PUMP STATION

HOUSE 2' OR LESS ABOVE
THE MAXIMUM HYDRAULIC
GRADIENT OF THE
UPSTREAM PUMP STATION

CLEANOUTS FOR DRAINS THAT PASS
THROUGH A BACKWATER VALVE SHALL BE
CLEARLY IDENTIFIED WITH A PERMANENT
LABEL STATING "BACKWATER VALVE
DOWNSTREAM".

SIDE SEWER FROM HOUSE
WITH HIGHER ELEVATION

SIDE SEWER FROM HOUSE
WITH LOWER ELEVATION

SEE SIDE SEWER CHECK
VALVE ASSEMBLY STANDARD
DETAIL S-26 (TO BE INSTALLED
ON SIDE SEWER FROM HOUSE
WITH LOWER ELEVATION)

SEE NOTE 2

6"X6" WYE

6" PIPE MIN.

10'(±) OR AS DIRECTED
BY THE ENGINEER

SANITARY SEWER LAKE LINE

NOTES:

1. CHECK VALVE ASSEMBLY IS PRIVATE AND SHALL BE THE PROPERTY OWNERS RESPONSIBILITY TO MAINTAIN.
2. ALL CLEANOUTS SHALL BE INSTALLED TO GRADE PER STANDARD DETAIL S-25.



**City of
Bellevue**

SEWER UTILITIES

TITLE

LAKE LINE CLEANOUT AND CHECK
VALVE ASSEMBLY INSTALLATION